

From: BCTAdmin@thameswater.co.uk
Sent: 15 January 2021 12:55
To: Planning Comments
Subject: 3rd Party Planning Application - SE/20/03750/FUL

EXTERNAL EMAIL: Do not click links or open attachments unless you recognize the sender and know the content is safe.

Sevenoaks District Council
Council Offices
PO Box 182, Argyle Road
Sevenoaks
Kent
TN13 1GP

Our DTS Ref: 68290
Your Ref: SE/20/03750/FUL

15 January 2021

Dear Sir/Madam

Re: PRESTON FARM, SHOREHAM ROAD, SHOREHAM, KENT , TN14

Waste Comments

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://developers.thameswater.co.uk/Developing-a-large-site/Apply-and-pay-for-services/Wastewater-services>

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development/Working-near-or-diverting-our-pipes>.

Thames Water would recommend that petrol / oil interceptors be fitted in all car parking/washing/repair facilities. Failure to enforce the effective use of petrol / oil interceptors could result in oil-polluted discharges entering local watercourses.

Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at thameswater.co.uk/buildingwater.

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to

provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments

There are easements and wayleaves running through the site . These are Thames Water Assets. Within the red line is a letting easement - TWA02397 for Telephone cable access tenant is 6M.

The company will seek assurances that it will not be affected by the proposed development. On the Map yellow dashed lines show the easements and wayleaves and the proposed development area is identified by a red outlined box.

The applicant should contact Thames Water to discuss their proposed development in more detail. All enquiries from developers in relation to proposed developments should be made to Thames Waters Developer Services team. Their contact details are as follows:

Thames Water Developer Services
Reading Mail Room
Rose Kiln Court
Rose Kiln Lane
Reading
RG2 0BY

Tel: 0800 009 3921
Email: developer.services@thameswater.co.uk
Email to follow with attached map.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online www.thameswater.co.uk , follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.