

Consultee Comments for Planning Application 21/00091/DIC

Application Summary

Application Number: 21/00091/DIC

Address: Rose Cottage Farm Church Road Newtown PO17 6LE

Proposal: Discharge of condition 10 (Drainage) of planning application 19/02754/FUL

Case Officer: Liz Marsden

Consultee Details

Name: WCC Drainage Engineer

Address: HCC Works Offices, Bar End Road, Winchester, Hampshire SO23 9NP

Email: Not Available

On Behalf Of: Drainage Engineer

Comments

21/00091/DIC

Cesspools are okay for foul drainage however a package treatment plant with suitably designed drainage field would be an upgrade.

Soakaway information needs detail including soil infiltration rates and soakaway dimensions