

Consultee Comments for Planning Application

20/08350/FULL

Application Summary

Application Number: 20/08350/FULL

Address: Second Floor Flat 87 Saltram Crescent London W9 3JS

Proposal: Erection of rear dormer and installation of Velux windows to front elevation and skylights to rear roof in connection with use of second floor and loft as a two bedroom flat.

Case Officer: Max Jones

Consultee Details

Name: Dave Nevitt

Address: City Hall, 64 Victoria Street, London SW1E 6QP

Email: Not Available

On Behalf Of: EH Consultation

Comments

No objection.

Stacking

Bathrooms and WCs should not be sited above living rooms or bedrooms.

I58AA Residential conversions - sound insulation.

The sound insulation in each new unit of a residential conversion should meet the standards set out in the current Building Regulations Part E and associated approved documents.