

Consultee Comments for Planning Application

S.21/0072/FUL

Application Summary

Application Number: S.21/0072/FUL

Address: Stroud General Hospital Trinity Road Stroud Gloucestershire GL5 2HY

Proposal: Proposed single storey extension to provide new entrance lobby together with associated external ventilation plant and alterations to windows

Case Officer: Tom Fearn

Consultee Details

Name: Mr David Jackson

Address: Stroud District Council, Ebley Mill, Ebley Wharf Stroud, Gloucestershire GL5 4UB

Email: Not Available

On Behalf Of: Environmental Health (E)

Comments

Tom,

With respect to this application, I would please request additional information in respect of the noise arising from the operation of the proposed air handling units and ventilation plant in terms of the sound levels likely to be experienced at the nearest dwellings, some of which lie as close as 20 metres away.

Further to this, I would also please request that the following condition be attached to any permission:-

No construction site machinery or plant shall be operated, no process shall be carried out and no construction-related deliveries taken at or dispatched from the site except between the hours 08:00 and 18:00 on Mondays to Fridays, between 08:00 and 13:00 on Saturdays and not at any time on Sundays, Bank or Public Holidays.

Regards,

Dave Jackson