

conform to BSS requireme All timber to be Tanatone of pressure treated at factory /yard prior to delivery on site to (Celbronzed or equivalent)

Any timbers cut on site are Trade Exterior Woodstain. to be resealed using Dulux

edge boards to lap 25mm 75x75mm weathered arris Close boarded fencing to rails with galvanised nails. minimum, fixed to ex. be 100x22mm to 6mm feather

rails. Plugged and screwed to piers. 100x100mm timber posts to be morticed to take arris

Bricks to be of approved facings suitable for use in

vement joint positions by Structural Engineer.

vertical centres <u>or</u> English Brickwork to be laid either nserted at 900mm horizor stretcher bond with ties Garden Wall bond. tal centres and 450mm

Good Building Guide No. 12000 ctrs and max 6000 from corners. For walls constructed from other materials please consult BRE Movement Joints in clay br icks to be located at max

Damp proof course to consist of min 3 courses of engineering bricks - at least 2 courses above ground level. Refer to Structural Engineer for details of foundation

Refer to Site Material Plan for brick type and colour.

solid brick projecting 15mm from the main facing wall. Copings to be 215mm solid engineering brick-on-edge on

EXTERNAL REFERENCE:

retcher course)

Brand: BARRATT / DAVID WILSON HOMES Range: 2010 / 2016 & -5 / -7 Title: Boundary Wall - Type 3

Detail No: **DB-SD13-013**

Drawn: GDT Checked: GDT Scale: VARIES Date: Dec 17

Rev:

Description: Stretcher course coping overhang reduced to 15mm. Additional plan added. Date: Mar 19

