



- General Notes
1. DO NOT SCALE.
 2. This drawing is to be read in conjunction with all other project drawings and specifications.
 3. All dimensions are in millimetre's unless otherwise stated.
 4. Should there be any conflict between the details indicated on this drawing and those indicated on other drawings the Project Engineer shall be informed PRIOR to construction on site.
 5. Until technical approval has been obtained from the relevant Authority, it should be understood that all drawings issued are Preliminary and NOT for construction. Should the Contractor commence site work prior to such approval being given, it is entirely at his own risk

SUDS MAINTNEANCE

- SURFACE WATER POLYPROPYLENE INSPECTION CHAMBERS SHOULD BE INSPECTED EVERY 3 MONTHS AND AFTER EVERY INTENSE RAINFALL EVENT.
- SURFACE WATER MANHOLES AND DRAINAGE RUNS SHOULD BE INSPECTED EVERY 3 MONTHS AND AFTER EVERY INTENSE RAINFALL EVENT.
- FOUL INSPECTION CHAMBERS AND DRAINAGE RUNS SHOULD BE INSPECTED MONTHLY TO ENSURE THAT THERE IS NO BUILD UP OF DEBRIS OR EFFLUENT.
- SURFACE WATER GULLIES, LINEAR DRAINAGE CHANNELS AND RAIN WATER PIPE OUTLETS SHOULD BE INSPECTED EVERY MONTH AND AFTER EVERY INTENSE RAINFALL EVENT. THEY SHOULD BE CLEARED OF ANY DEBRIS THAT MAY HAVE COLLATED WITHIN. DURING AUTUMN IT MAY BE PERTINENT TO INCREASE INSPECTIONS TO EVERY TWO WEEKS TO ENSURE THAT ANY BUILD UP OF LEAVES IS REMOVED FROM THE SYSTEM.
- PERMEABLE PAVING BLOCKS SHOULD BE INSPECTED MONTHLY AND AFTER EVERY INTENSE RAINFALL EVENT. THE SURFACE OF THE PERMEABLE PAVING SHOULD BE SWEEPED AT EACH INSPECTION AND ANY DEBRIS, SUCH AS LEAVES REMOVED.
- SURFACE WATER ATTENUATION FACILITY TO BE INSPECTED MONTHLY AND AFTER EVERY INTENSE RAINFALL EVENT. ANY DEBRIS COLLATING IN THE SURROUNDING INSPECTION CHAMBERS OR VENTING CHAMBER IS TO BE REMOVED. THE FLOW CONTROL CHAMBER THAT THE ATTENUATION TANK DISCHARGES TO SHOULD ALSO BE INSPECTED MONTHLY WITH ANY DEBRIS REMOVED FROM THE SUMP AND FROM THE HYDRO-BRAKE.
- BASIN TO BE LITTER PICKED MONTHLY WITH THE OUTLET PIPES INSPECTED MONTHLY
- THE ABOVE INSPECTION AND MAINTENANCE REGIMES ARE FOR GUIDANCE ONLY.

IN ANY EVENT, ALL INSPECTION CHAMBERS, MANHOLES, DRAINAGE RUNS, LINEAR DRAINAGE CHANNELS, GULLIES, RAIN WATER PIPE OUTLETS AND ATTENUATION TANKS AND PERMEABLE PAVING SHOULD BE INSPECTED AND MAINTAINED IN LINE WITH THE CHOSEN MANUFACTURERS GUIDANCE TO ENSURE MAXIMUM EFFICIENCY.

GENERAL
THE WHOLE SITE TO BE LITTER PICKED ON A MONTHLY BASIS TO ENSURE NO DEBRIS CAN BE WASHED DOWN GULLIES, PIPES CHANNELS ETC.

EVERY 5 YEARS MINIMUM, THE SITE DRAINAGE NETWORK SHOULD BE PRESSURE JETTED AND WASHED DOWN, INCLUDING CHANNELS AND GULLIES ETC

REV	AMENDMENT	BY	CHK	DATE	
CE	PROJECT EXECUTION CLASS: S3				
All materials supplied in relation to those specified on this drawing are to be CE marked in accordance with the European Union Declaration of conformity					
DRAWING STATUS					
PRELIMINARY					
CONSULTING ENGINEERS LTD CIVIL STRUCTURAL DESIGN The Old Church Offices Shelton New Road Hoptonville, Stoke on Trent ST4 6DF Email: mail@c2cconsulting.co.uk Telephone: 01782 980330					
CLIENT					
JESSUP BROTHERS LIMITED					
PROJECT					
BATTLEFIELDS					
DRAWING TITLE					
SUDS MAINTENANCE PLAN - Sheet 2 of 2					
SHEET SIZE	SCALE	DATE	DRAWN	CHECKED	STATUS
A1	1:500	29.10.20	DW	GS	S3
PROJECT No.	DRAWING No.				REV
200498	C2C - XX - XX - P - C				108 P01