

Mid Suffolk District Council Planning Department Endeavour House Russell Road Ipswich IP1 2BX

Suffolk Fire and Rescue Service

Fire Business Support Team Floor 3, Block 2 Endeavour House 8 Russell Road Ipswich, Suffolk IP1 2BX

Web Address: http://www.suffolk.gov.uk

Date: 22/01/2021

Dear Sirs

Elm Vale Cottage, Denmark Hill, Palgrave, Diss IP22 1AB Planning Application No: DC/21/00282/FUL

I refer to the above application.

The plans have been inspected by the Water Officer who has the following comments to make.

Access and Fire Fighting Facilities

Access to buildings for fire appliances and firefighters must meet with the requirements specified in Building Regulations Approved Document B, (Fire Safety), 2019 Edition, Volume 1 - Part B5, Section 11 dwelling houses, and, similarly, Volume 2, Part B5, Sections 16 and 17 in the case of buildings other than dwelling houses. These requirements may be satisfied with other equivalent standards relating to access for fire fighting, in which case those standards should be quoted in correspondence.

Suffolk Fire and Rescue Service also requires a minimum carrying capacity for hard standing for pumping/high reach appliances of 15/26 tonnes, not 12.5 tonnes as detailed in the Building Regulations 2000 Approved Document B, 2019 Edition.

Water Supplies

Suffolk Fire and Rescue Service records show that the nearest fire hydrant in this location is over 664m from the proposed build site and we therefore recommend consideration is given to the provision of water for firefighting purposes.

/continued

OFFICIAL

OFFICIAL

Should you need any further advice or information on access and fire fighting facilities, you are advised to contact your local Building Control or appoint Approved Inspector in the first instance. For further advice and information regarding water supplies, please contact the Water Officer at the above headquarters.

Yours faithfully

Water Officer

Suffolk Fire and Rescue Service

Copy: Craig@beecharchitects.com