



Sika liquid applied top coat, Sika liquid applied embedment/ base coat and Sika self adhesive carrier membrane. Installed as per manufacturers details and guidelines. NBS J31

Decotherm PIR tapered insulation, providing min. 1:80 slope to hidden gutter - refer to section BB. NBS J31

Parapet upstand: 38x90mm site treated s.w frame sheathed with 18mm OSB 3/WBP ply sheathing and 40mm th. Steico Universal (as note below).

Zinc parapet coping profile
site treated s.w batten at 600mm centres, 18mm marine grade ply over

Insect mesh
Aluminium support profile

25x50mm s.w batten and 18mm marine grade ply upstand

Zinc saddle piece (finish to match roof cover)

Double standing seam roof covering by Rheinzink (or similar to be approved). Black finish to be confirmed. Installed as per manufacturers guidelines and details. NBS H74

Separating layer, structured underlay, as per Rheinzink details (or similar to be approved)

18mm marine grade plywood

50mm ventilated cavity formed with 50x50mm site treated s.w battens, fixed as per note below

60mm th. Steico Universal wood fibre external sheathing board. Fixed with Ejoyt TKR150, via 50mm battens above. 150mm length to provide min. embedment to timber rafters of 40mm, as per manufacturers guidelines. NBS K11/436

S-Vap Self Adhesive Vapour Barrier or similar to be approved. Installed as per manufacturers instructions. NBS J31

22mm larch sarking boards. NBS K20/220

200x50mm FSC certified untreated s.w rafters at 400mm centres. To SE specification. Full filled with pavaflex woodfibre insulation batts, as per manufacturers instructions. NBS P10/140

200x50mm FSC certified timber joists @ 400mm c/c as per SE design and specification.

CV30/6 CV cavity strip by Envirograph or similar to be approved. Adhered to external sheathing board as per manufacturers instructions. NBS P10/435

18mm smart-ply pro-passive board with integrated barrier - NBS K11/435 taped at all joints and junctions with suitable tape for substrate NBS P10/436

Timber/timber, steel fitch beam to S.E design and specification. Fixing of beam to existing posts to be agreed

50mm service zone formed with 50x50 untreated s.w battens at 600mm centres

12.5mm gyroc fireline with skim finish. NBS K10/245

Notes / Key:

Do not scale from this drawing. All existing dimensions to be checked on site prior to commencement of works or manufacturing of components. Any discrepancies to be brought to the attention of the architect - if in doubt, ask.

This drawing is the copyright of John Gilbert Architects Ltd. No copying or distribution of this drawing or any part thereof is permitted without prior written permission.



201 White Studios, 62 Templeton Street, Glasgow, G40 1DA
Tel: 0141 551 8383
Web: www.johngilbert.co.uk

Client
ABOVE ADVENTURE

Project
WOODSTOCK STREET CHURCH

Title
FLAT ROOF TO RIDGE JUNCTION

Project Status
CONTRACT

Job No
03749 Scale at A3
1:5

Drawn by
SRA Date of issue

Rev.	Amendment	Date
B	RAFTER/ INSULATION DEPTH	16.12.19

Drg No.
[37]43 Rev
B