

±73.595

Existing cast iron finial
Ensure it is securely fixed
Repaint in place as per approach in [37]37

Lightning protection system to be renewed to BS EN 62305
Tape to be located to north elevation of spire

Theoretical zone of protection for lightning system (45degrees)

Area of significant moss growth

Plant growth
Carefully remove and treat
area with biocide to prevent
regrowth

Renewal of existing louvres as per [PS]20 and [31]04

Cast iron finial to be restored as per [31]40

Roof vent reinstated as per [37]19

Ridge tiles rebedded or renewed as [37]01

Carefully remove and point
up screw holes

Light fitting
Carefully remove and point
up screw holes

Existing porch to be removed.

Disputed extension that
refer to dwg. [PS]03, [PS]04,
[PS]05 and [PS]08

New 1:21 gradient paths up to
1:15 gradient main entrance
access ramp. See dwg. [PS]06.
Refer to detail [02]00 for raised
path detail, ensuring existing
four vents remain unobscured

- 150mm full stone indent
Ashlar faced
- 150mm full stone indent
Rubble faced
- Full-stone tracery / moulded
/ mullion indent
- Area requiring repointing
6mm Rubble joints
NHL 3.5 - 1:2
- Area requiring repointing
6mm+ Rubble joints
NHL 3.5 - 1:2.5
- Area requiring repointing
3mm ashlar joint
NHL 3.5
- Area requiring repointing
3mm ashlar joint
NHL 5
- Window mesh installed
- Movement crack to be
repaired
- Zone where service penetrations
are acceptable in principle, all new
cores require CA and HES sign off

Notes / Key:
ALL CUTTERS TO EXISTING
BUILDINGS TO BE
REPLACED
EXISTING SLATE ROOF
REPAIRS AS PER [PP]03 AND
NBS H62
LEAD REPAIRS AS PER
DETAIL SERIES 37 AND NBS
H71
STONE INDENTS
GENERALLY A MINIMUM OF
150MM DEEP AND CARRIED
OUT IN CORNCOCKLE
SANDSTONE - SAMPLE TO
BE APPROVED BY CA AND
HES ON SITE

Full extent of stone repairs
and repointing to be agreed
on site once scaffold is
erected, stone repairs and
repointing not to commence
until sign off for scheme is
received from HES.

Do not scale from this drawing.
All existing dimensions to be checked on site prior to
commencement of work or manufacturing of components.
Any alterations to the scope to be the pleasure of the
architect. If in doubt, ask.
This drawing is the copyright of John Gilbert Architects Ltd.
No copying or distribution of this drawing is permitted
without the prior written permission.

John Gilbert ARCHITECTS
201 White Street, 44 Temple Street, Glasgow, G2 6DA
Tel: +44 (0) 141 879 1111
Web: www.jga.co.uk

Client
ABOVE ADVENTURE
WOODSTOCK STREET CHURCH

Title
PROPOSED SOUTH ELEVATIONS

Project Status
Job No. **03749** Scale of Rev. **1:50**
Drawn by **SRA** Date of Issue **06/01/21**
Rev. **01**