



Chesterfield Borough Council
Planning Service
Development Management
Town Hall
Chesterfield
S40 1LP

For the Attention of Helen Frith

Via Email :

[REDACTED]

Contact Name & Address
Hazel Lawton

East Area – Chesterfield Office
Chesterfield Community Fire
Station
Spire Walk Business Park
Braidwood Way
Chesterfield
Derbyshire
S40 2WH

Contact Telephone No & Ext

[REDACTED]

Our Reference
J589-971/HL/SLR

Your Reference
CHE/20/00869/REM

Date
22 January 2021

Dear Madam

RESIDENTIAL DEVELOPMENT: LAND TO THE NORTH OF NORTHMOOR VIEW BRIMINGTON DERBYSHIRE

Thank you for your letter dated 21 January 2021 informing us of the planning application for the above project.

Goodwill Advice

The following recommendations, whilst they may not be enforceable, are offered as general advice in the interests of greater fire safety.

The Fire and Rescue Authority strongly recommend the Installation of a Domestic Sprinkler System in the proposed premises, however should you choose not to install a Domestic Sprinkler System at this stage, the Fire and Rescue Authority would like to recommend that you provide a minimum 32mm water supply capable of delivering the required volumes which would allow an installation to be carried out easier and at less cost should this be proposed in the future.

If I can be of any further assistance to you in this matter please do not hesitate to contact me.

Yours faithfully

[REDACTED]

Authorised Fire Safety Inspecting Officer
And on behalf of the Derbyshire Fire and Rescue Authority

email: [REDACTED]
www.derbys-fire.gov.uk

Chief Fire Officer / Chief Executive
Gavin Tomlinson MBA MIFireE

