

Consultee Comments for Planning Application 21/00039/OUT

Application Summary

Application Number: 21/00039/OUT

Address: Land East Of Calvmoor 59 Common Lane Welton East Riding Of Yorkshire HU15 1PT

Proposal: OUTLINE - Erection of three detached dwellings (all matters reserved)

Case Officer: Mrs Karen Abba

Consultee Details

Name: . Yorkshire Water Services Ltd Developer Services

Address: Yorkshire Water Services Ltd, Developer Services Pre Development Team PO Box 52,
Bradford BD3 7AY

Email: Not Available

On Behalf Of: Yorkshire Water Services Limited (YWSCA)

Comments

Application details reviewed - based on the information submitted (surface water drainage stated as soakaway (foul only to sewer)), no observation comments are required from Yorkshire Water. Developer to please note - If surface water disposal changes from proposed soakaway to public sewer network, YW will need to be re-consulted as further details will be required.