

Service Timber Limited Planning Ref: 21/00149/PLF

AIR QUALITY ASSESSMENT

- This was up-loaded as part of the original application. Please find attached Version 2 which includes amendments to match the changes to the application form.

SURFACE WATER ASSESSMENT

- Confirmation that the proposals do not involve erection of extensions or new wood chip store therefore there is no increase to surface water discharge.

NOISE IMPACT ASSESSMENT

- As discussed the biomass boiler and associated fuel feed system will be contained within the existing building and will not produce any noise external to the building over and above the existing timber manufacturing equipment already located within the production area of the building.

FUEL DELIVERY

- The intention is to provide the wood chip fuel on site from the waste products of the production of furniture manufacturing. The fuel delivery route was included as there may be 'ad hoc' fuel delivery requirements during high fuel use periods when the waste products used to produce the wood chip fuel are depleted.