

	<b>Acoustic Information for Spraymate Booth with 710mm Impeller</b>	
Site: IRG Wolverhampton	Project Ref: STL1404	
By: Teodor Cristurean	Booth Type: STL Spraymate	

The information given is to enable an evaluation of the calculated sound levels at the rear and front boundaries. The data from the spray booth extract ventilation system have been used as this is the predominant sound source.

**Fan Impeller details**

Impeller Type – Backward Curved

Fan Speed – 1400 rpm

Duty 26,000 m3/hr at 400Pa

**Duct size**

The duct used for the inlet and extract fan will be 630mm galvanised ducting. The inlet duct will terminate outside the back wall with a beard beak. The extract duct will exit the back wall and it will run up alongside the wall and it will terminate at 3m above the ridge.

**Fan Acoustic Data**

The fan curve shows a “A” decibel free outlet sound power level LW(A)8

Fan Sound Power Level = 98dB(A) LWA8

**Sound Level calculated at Boundary**

From the fan manufactures acoustic information the single level has been split across the octave band spectrum. Installation losses have been applied for the ducted system and terminal. Free field reduction has been applied for the different distances between the outlet with the front and rear boundaries

	Octave Band Mid-Frequency (Hz)								Total
	63	125	250	500	1k	2k	4k	8k	
"A" Weighted Front Boundary	13	28	25	22	33	28	22	12	36
"A" Weighted Rear Boundary	19	34	31	28	39	34	28	18	42

**Resultant “A” Weighted Sound Level Free Field at Boundary**

Front Boundary = 36 dB(A)

Rear Boundary = 42 dB(A)

**Sound Evaluation at Boundary**

Using information from the Centre for Hearing and Communication the resultant dB(A) levels can be compared with levels as a point of reference

- 10 dB(A) normal breathing
- 20 dB(A) whispering at 5 feet
- 30 dB(A) soft whisper
- 40 dB(A) quiet residential Area
- 50 dB(A) rainfall
- 60 dB(A) normal conversation
- 70 dB(A) Freeway Traffic



## Acoustic Information for Spraymate Booth with 710mm Impeller

Site: IRG Wolverhampton

Project Ref: STL1404

By: Teodor Cristurean

Booth Type: STL Spraymate

The resultant sound levels at the boundary equates to a level that is similar to the background noise in a quiet residential area. The facility sits in a light industrial area that also backs onto a retail area. It can be established that the resultant sound emitted from the booth ventilation system is below the background level of the area. As a result there will be no noise impact at the properties boundaries.