

# **Consultee Comments for Planning Application 20/03665/PLF**

## **Application Summary**

Application Number: 20/03665/PLF

Address: Land North Of 13 Hazel Avenue Withernsea East Riding Of Yorkshire HU19 2PQ

Proposal: Erection of a dwelling and garden store

Case Officer: Mr Daniel Allen

## **Consultee Details**

Name: . Land Drainage

Address: East Riding Of Yorkshire Council, County Hall, Cross Street Beverley, East Riding Of Yorkshire HU17 9BA

Email: Not Available

On Behalf Of: Land Drainage

## **Comments**

The Land Drainage Team (LDT) have no objections to the proposals.

NOTE - If soakaway tests fail on site then the applicant must consult with Yorkshire Water for permission to discharge surface water to the public sewer.

GF LDT