



can be extended to incorporate additional

sockets and new lighting.

NOTES

DO NOT SCALE FROM THIS DRAWING,
ALL DIMENSIONS TO BE CHECKED ON SITE.

COPYRIGHT PROTECTED.

4.5 Socket outlets will be installed in accordance with the recommendations within the 4.6 of the bullding regulations and BS 7671: 2008. Final position to be advised by client to suit equipment

Light Switches should be positioned at a height of 1100mm above FFL. Standard Switches should be at least 400mm above FF.

All new sanitary drainage pip work will be in accordance with BS EN 1610:12056-1:2000m BS EN 752-3:1997(Adm2), BS EN 752-4:1998 and BS 1610:1998

## New Extraction

The existing building has no extract provision. The proposal seeks to provide new mechanical extraction the kitchen, WC and servery areas. Supply air is via openable louvers within existing windows.

Kitchen. There shall be no frying or intensive cookinin the kitchen. The kitchen shall prepare soups, bread and warm up dishes. New mechanical extraction shall be installed capable of extracting at least 60l/s (intermittent)

Servery - Same as kitchen. Servery used as food prep and heating of food. New mechanical extraction shall be installed capable of extracting at least 60l/s (intermittent)

WC. To be cabable of extracting at least 3 air changes per hour.

A

REV DATE DESCRIPTION

Sara Capaldi

Proposed New Deli Fit Out 75 Hector Road Glasgow G41 3QD

DRAWIN

Proposed Floor Plan

CONSULTANT No	SCALE	DATE	DRAWN	CHECKE
mAC	1:50	19.11.20	SM	-
PROJECT No	DISCIPLINE	DRAWING No	STATUS	REV
20020	Α	P-005	F	В



