

**ROOKERY FARM, DEPDEN  
SCHEDULE OF NON MATERIAL AMENDMENTS TO APPLICATIONS DC/20/0372/HH &  
DC/20/0373/LB**

We are applying for approval to make the following amendments to the above approvals.

| Item                 | Current Approval   | Proposed change   |
|----------------------|--|---|
| Roofing materials    | The kitchen extension is to be covered in slate due to the shallow pitch whilst the annexe is covered in clay plain tile.                                    | To create a uniform appearance both kitchen and annexe are to be covered in slate as approved for the kitchen<br><a href="http://www.sigaslate.co.uk">http://www.sigaslate.co.uk</a>  |
| Rooflight spec.      | The approval is to use a Roofmaker Luxlite Conservation". Having detailed the waterproofing the rooflight would project 150mm above the slate roof covering. | To allow the rooflight to sit flush with the slate we will change to "The Rooflight Company ref: CR013-3" 1141 x 1440mm as<br><a href="https://www.therooflightcompany.co.uk/assets/media/images/technical%20info/conservation%20rl/installation%20details/btr/C_R_CRSF_LS_B.pdf">https://www.therooflightcompany.co.uk/assets/media/images/technical%20info/conservation%20rl/installation%20details/btr/C_R_CRSF_LS_B.pdf</a> |
| External cladding    | Treated softwood feather edge boards, 175mm in width and 28 / 8mm thick finished in dark grey stain.   | Oak feather edge boards, 175mm in width and 28 / 8mm thick, unfinished  |
| Windows to extension | Softwood double glazed as drawing 04.0   | Horizontal glazing bars to be removed as drawings 04.A and 02G<br>NOTE! Windows to existing house are unchanged.  |

Ref: ms/6104

Date: 15 January 2021