

Stone with poor pointing (appears to have had linostone applied over face and joints are not defined)

Linostone or cement to be carefully removed. Assume 30% indentation, 50% application of ST.one mortar repair and 20% brushing back required to substrate.

Indents required

mortar

lime-based mortar

system




Notes

Copyright and not to be reproduced without the consent of Holmes Miller Holmes Miller accepts responsibility for this document only to the commissioning Party and not to any other. Holmes Miller does not accept liability for accuracy or veracity of survey information provided by others and horizontal dimensions and levels provided by Holmes Miller and based on survey information provided by others must be verified on site DO NOT SCALE: Use figured dimensions only

= = = = = Existing roof access

- Existing Safety Line system -CHF-3A-Ref.06
- Assumed linostone to be removed and stone repaired underneath -CHF-3A-Ref.04

- Areas of stone to be investigated and joints defined - CHF-3A-Ref.04
- Discoloured stone cleaned using DOFF system -CHF-3A-Ref.05



Holmes Miller

89 Minerva Street Glasgow G3 8LE 0141 204 2080 www.holmesmille miller co

Project

4687 City Halls & Old Fruitmarket Roofworks City Building

Drawing Name

Zone 3 - East Elevation Northern Half

Scale @A3	Checked	Revision
1:100	DJ	P01

Drawing Number

CHF-HML-03-XX-DR-A-12114

Joints to be raked out and repointed in lime-based

Discoloured stone to be cleaned using DOFF system

Area of stone to be raked out and repointed in

Damp stone - source to be stopped and stone allowed to dry out prior to treating with DOFF