

Tony Le Warne

From: Stone, Joshua <jstone@silcockdawson.co.uk>
Sent: 03 June 2020 15:52
To: Tony Le Warne
Cc: Troote, Simon; Christian Lawrence; Marta Batraniec
Subject: RE: EEHS - Planning conditions

Hi Tony,

Here is the relevant information as requested.

- 2x Monodraft x-air size 170 windcatchers located in the roof of the clubhouse. 1247x1247x1333 Lxwxh (mm)
- 4x MVHR units XBC-25-H-NES located in each large changing room/shower room. 1600x1000x260 Lxwxh (mm). Intake and exhaust ductwork to terminate at roof level via roof cowls.
- 1x Opus60S extract fan located in the Comms room. 300x260x260 Lxwxh (mm). Exhaust ductwork to terminate at roof level via roof cowl.
- 1x AVT6 extract fan located in the maintenance store. 1729x1024x545 Exhaust ductwork to terminate at roof level via roof cowl.
- There are no Louvres required apart from the louvred plant room double door

Further information can be located on the schedules and ventilation drawings.

Kind Regards

Joshua Stone

**SILCOCK
DAWSON**
& PARTNERS

Silcock Dawson & Partners Ltd
11th Floor
Colston Tower
Colston Street
Bristol, BS1 4XE
T +44 (0)117 929 4749
F +44 (0)117 922 1456

www.silcockdawson.co.uk

CIBSE
LOW | **CARBONCONSULTANTS**

 please consider the environment before printing this e-mail

Electronic mail is not secure and may not be authentic. If you have any doubts as to the contents please telephone to confirm. The information contained in this message is confidential and is intended for the addressee

only. If you have received this message in error or there are any problems, please notify the originator immediately. The unauthorised use, disclosure, copying or alteration of this message is strictly forbidden. Opinions, conclusions and other information expressed in this message are not given or endorsed by Silcock Dawson & Partners unless otherwise indicated by an authorised representative independent of this message.

From: Tony Le Warne [mailto:tony@clarchitects.co.uk]
Sent: 03 June 2020 11:11
To: Troote, Simon
Cc: Christian Lawrence; Marta Batraniec
Subject: RE: EEHS - Planning conditions

Hi Simon,

We are preparing the information for the discharge of the planning conditions for EEHS Development. Can you please provide the relevant information to satisfy the following condition?

I apologise if you have previously provided the information.

31	1, 2	Fans, Louvres etc		Prior to the installation of fans, Louvres etc on the School Development, the following specification shall be submitted and approved in writing with the Council:
----	------	-------------------	--	--

Regards

Tony Le Warne

CLArchitects
127 Sandgate Road
Folkestone, Kent
CT20 2BH
01303 647 233

tony@clarchitects.co.uk



Please consider the environment before printing this e-mail

The contents of this email and any attachments are confidential to the addressee(s). If you are not the addressee, please advise sender immediately and delete this email. The contents of this email and attachments are copyright Christian Lawrence Architects Ltd and may not be transferred or copied to a third party, or published without written approval from the copyright holder. Reasonable means have been used to prevent virus infection, but Christian Lawrence Architects Ltd will not accept liability for any damage sustained due to virus infection.

This email is sent for and on behalf of **CLArchitects** a limited company registered in England and Wales Registered number: 07595580

Disclaimer

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful.

This email has been scanned for viruses and malware, and may have been automatically archived by **Mimecast Ltd**, an innovator in Software as a Service (SaaS) for business. Providing a **safer** and **more useful** place for your human generated data. Specializing in; Security, archiving and compliance. To find out more [Click Here](#).