



Development Management <developmentmanagement@sutton.gov.uk>

Fwd: Planning Application Decision - DM2020/00535

1 message

Sally Squires 

7 April 2021 at 08:49

To: Development Management <developmentmanagement@sutton.gov.uk>

Cc: Ben Rochford 

Email 1 of 2

Hi
A LBS journal transfer will be prepared to cover the £115 fee for the discharging of condition 2 relating to the planning and listed building consents for the above application.
Historic England have agreed to the proposals in an email of 26th March as below: the report has been modified to include the mortar mix as suggested by Alex Bowring of Historic England and I will forward that via a separate email.
Please can you register and process this application.
Many thanks
Sally

Hi Sally

Many thanks for the report – the sample panels look great and this looks like a good way forward for the rebuilt wall.

The report should satisfy the condition that we had suggested, though if it is to be formally submitted for this purpose, I suggest that it should also include the mortar spec. I think we had previously agreed that a NHL 3.5 mortar mix would be suitable in this instance.

Kind regards,

Alex Bowring

Inspector of Historic Buildings and Areas

London and South East Region

4th Floor, Cannon Bridge House, 25 Dowgate Hill, London EC4R 2YA


