

Planning Comments

From: Patrick Cheung
Sent: 18 November 2019 15:01
To: Planning Comments
Subject: 19/05000/HYB
Attachments: Waste Management Guidance for Developers - SDC (Updated June 2019).pdf

Hello there

Thanks for consulting with our department.

From our perspective, it is important that the develops liaise with us as early as possible to ensure that waste collections can proceed without any issues. If a formal planning application is received, we would expect the following to form part of the application:

- A site map showing the swept path analysis of our largest vehicle
- If there are flatted properties, bin stores shown on the plans must be within 15 metres of road access (and the adequate number of bins to be shown on the plans).

Please send over a copy of our Waste Management Guidance for Developers that is attached.

Patrick Cheung

Recycling Co-ordinator

Direct Services

Sevenoaks District Council, Dunbrik Depot, 2 Main Road, Sundridge, Kent, TN14 6EP

patrick.cheung@sevenoaks.gov.uk

Tel: 01732 227420 Mobile: 07849 077587

www.sevenoaks.gov.uk