

Consultee Comments for Planning Application 21/00840/ADFULL

Application Summary

Application Number: 21/00840/ADFULL

Address: Ground Floor Lords Cricket Ground St John's Wood Road London NW8 8QN

Proposal: Details of details of the ventilation system to get rid of cooking smells pursuant to Condition 28 of planning permission dated 29 March 2019 (RN: 18/08510/FULL).

Case Officer: Stuart Croll

Consultee Details

Name: Mr Mark Walshe

Address: 64 Victoria Street, London SW1E 6QP

Email: Not Available

On Behalf Of: Plant And Equipment

Comments

I require more information regarding this application.

The application does not demonstrate where the kitchen extract terminates relative to the height of other buildings in the area; namely off site receptors. The application would have to meet the councils kitchen extract guidance. We require plans demonstrating the termination point of the kitchen extract, how that relates to receptors, including the distance and also the height of the termination point of the kitchen extract relative to receptors.