

Foundations and Sub-structure
Foundations to be grade C25 ready-mixed concrete to reach a minimum strength of

28N/MM s.q. at 28 days. Foundations to be built off solid original ground and to comply with Approved

Type A concrete blockwork used below ground level and cavity backfilled with lean mix

concrete upto external ground / path level. Ground Floor Construction

Solid floors to consist of 70MM 'chicken wire' reinforced sand cement screed on vapour control barrier on 100mm insulation on 150mm thick Grade C25 concrete floor slab on 1200 gauge visqueen D.P.M. on 150mm well compacted sand blinded hardcore to acheive minimum 'U' Value of 0.25W/m s.q.K.

External Wall Construction External walls to consist of either 13mm waterproof render on 100mm Class A blockwork or 102mm facing brickwork with 100mm cavity partially filled with 'Celotex' CW2040 (40mm) with inner skin of 100mm dense Class A concrete blockwork with

12.5mm plasterboard internally to achieve a minimum 'U' Value of 0.35 W/m s.q. k. Wall ties to be stainless steel 250mm double triangular pattern at 750mm horizontal centres and 450mm vertical centres and staggered with ties every 225mm at corners

Where cavities close at window and door reveals 100mm insulation Plus Cavity Closure System to be installed as manufacturers instructions.

'Hyload' 110mm horizontal D.P.C. to be incorporated a minimum of 150mm above external ground / path level and to lap with D.P.M. 150mm vertical D.P.C. wherever cavity closes

and below all window cills and door thresholds. 12.5mm sheet Supalux cavity barrier to close tops of cavity walls including eaves and

Lintels unless otherwise indicated to be I.G. type L1/S100 with D.P.C. tray over as per manufacturers instructions and to have a minimum end bearing of 150mm.

Ground floor walls to be 100mm dense concrete blockwork in 1:1:6 cement/Lime/Sand

mortar bonded to exteranl wall inner skin.

200x50 First floor joist at 450mm centers to be Grade C24 timber with 25x50mm herringbone strutting at mid-span with 19mm plywood floorboarding to top and 12.5mm plasterboard and skim to underside.

Joist strapped to all walls on all elevations with 30\*5MM 'Catnic' steel anchoring straps at 2m maximum centres to comply with approved document A1 / 2 of Building

Roof Construction
Pitched roof to match existing (if possible) with synthetic slates on 50x25mm softwood treated battens on 50x50mm treated counter battens on 'Tyvek' Supro Plus breather membrane on Grade S.C.3 grade softwood pafters (with Grade c24 ceiling joists) or roof trusses to BS5268 part 3 : 1985.

Wall plates to be 100x50mm treated softwood bedded on sand / cement mortar and secured to external walls with 1200mm long x 30x5mm galvanised steel vertical restraint straps at 2m maximum centres.

Roof insulation to be 150mm 'Crown Wall' insulation laid between ceiling joists to butt up against cavity wall insulation without a gap with a secon layer of 100mm 'Crown Wool' insulation laid over joists tucked tightly up against breather membrane to underside of roof covering. Construction to acheive hinimum 'U' Value of 0.16 W/m s.q.

Ceiling of 12.5mm plasterboard and skim with 'Tyvek Vapour Control Layer VCL SD2 as

minimum of 450mm below ground level with a minimum fall of 1:40 in 150mm Class B granular bed and surround. All drainage to comply with Aprroved Document H of the

inspection chamber, up to 600mm invert, or 450mm diameter universal inspection chamber up to 1m invert installed as per manufacturers instructions.

Rainwater goods to be 'Osma' Roundline / square line fitted as per manufacturers

Wastes to be 'Osmaseal' 38mm to sink unit, shower and bath, 32mm to wash hand basin. All to be fitted with 75mm deepseal traps and all as manufacturers instructions.

All habitable rooms to be provided with trickle ventilators to achieve 8,000 sq.mm and to have a openable area of at least 1 / 20th of the floor area.

All other rooms to have trickle ventilators to achieve 4,000 sq.mm

Kitchen / utility rooms to be provided with mechanical extract fans capable of extracting air at a rate of not less than 60 litres per second.

Bathroom / shower room to be provided with a fan capable of extracting 15 litres per

All fans to have a 15 minute over-run facility.

Glazing, Windows and Doors All windows to be constructed of either timber or u.P. V.C. and double glazed with draught seals to all openable elements with 16mm sealed glazing units with 'inner skin' of low E glass with low-E,

All glazing to doors and side screens and any glazing pane to a window totally or partially lower than 800mm

above finished floor level to be of toughened saftey glass as per B.S. 6206:1981 <u>Electrical Switches</u>
All light switches, power points etc. to be located between 450mm and 1200mm above finished floor level.

## FOR PLANNING PERMISSION

PORCH SIZE & TYPE REVISED, EXTENSION SET BACK AND GARAGE DOOR HEIGHT REDUCED.

Mr S. DAVIES 2 BIRCHGROVE, TRETHOMAS, CAERPHILLY, CF83 8BQ

PROPOSED DOUBLE/SINGLE STOREY EXTENSION TO SIDE AND PORCH TO FRONT (SHEET 2 OF 3)

EXISTING GROUND AND FIRST FLOOR PLANS

Original Size	Α1	Sca	AS SHOWN
Date		Dra	wing number
	MAR 2020		SD/101A