


Civic Engineers		Page 1
Carvers Warehouse 77 Dale Street Manchester, M1 2HG		
Date 09/04/2021 10:19 File 846-04 Corner Building ...	Designed by ThomasC Checked by	
Innovyze	Network 2020.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	1	PIMP (%)	100
M5-60 (mm)	18.000	Add Flow / Climate Change (%)	0
Ratio R	0.352	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	50	Maximum Backdrop Height (m)	1.500
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits




Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.033	4-8	0.013

Total Area Contributing (ha) = 0.046


Total Pipe Volume (m³) = 0.243

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	5.000	0.050	100.0	0.046	5.00	0.0	0.600	o	100	Pipe/Conduit	
1.001	5.000	0.050	100.0	0.000	0.00	0.0	0.600	o	100	Pipe/Conduit	
1.002	9.328	0.093	100.0	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	45.86	5.11	53.170	0.046	0.0	0.0	0.0	0.77	6.0	5.7
1.001	45.46	5.22	52.870	0.046	0.0	0.0	0.0	0.77	6.0	5.7
1.002	44.90	5.37	52.820	0.046	0.0	0.0	0.0	1.00	17.8	5.7

Civic Engineers		Page 2
Carvers Warehouse 77 Dale Street Manchester, M1 2HG		
Date 09/04/2021 10:19 File 846-04 Corner Building ...	Designed by ThomasC Checked by	
Innovyze	Network 2020.1	

Area Summary for Storm

Pipe Number	PIMP Type	PIMP Name	PIMP (%)	Gross Area (ha)	Imp. Area (ha)	Pipe Total (ha)
1.000	-	-	100	0.046	0.046	0.046
1.001	-	-	100	0.000	0.000	0.000
1.002	-	-	100	0.000	0.000	0.000
				Total	Total	Total
				0.046	0.046	0.046

Free Flowing Outfall Details for Storm


Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.002		54.600	52.727	52.200	0	0

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	1	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	18.000	Storm Duration (mins)	30
Ratio R	0.352		

Civic Engineers		Page 3
Carvers Warehouse 77 Dale Street Manchester, M1 2HG		
Date 09/04/2021 10:19 File 846-04 Corner Building ...	Designed by ThomasC Checked by	
Innovyze	Network 2020.1	

Online Controls for Storm


Hydro-Brake® Optimum Manhole: 3, DS/PN: 1.002, Volume (m³): 3.6

Unit Reference	MD-SHE-0100-5000-1350-5000
Design Head (m)	1.350
Design Flow (l/s)	5.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	100
Invert Level (m)	52.820
Minimum Outlet Pipe Diameter (mm)	150
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.350	5.0
Flush-Flo™	0.400	5.0
Kick-Flo®	0.829	4.0
Mean Flow over Head Range	-	4.4

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	3.3	1.200	4.7	3.000	7.3	7.000	10.9
0.200	4.6	1.400	5.1	3.500	7.8	7.500	11.2
0.300	4.9	1.600	5.4	4.000	8.3	8.000	11.6
0.400	5.0	1.800	5.7	4.500	8.8	8.500	11.9
0.500	5.0	2.000	6.0	5.000	9.2	9.000	12.2
0.600	4.8	2.200	6.3	5.500	9.7	9.500	12.6
0.800	4.2	2.400	6.5	6.000	10.1		
1.000	4.4	2.600	6.8	6.500	10.5		


Civic Engineers		Page 4
Carvers Warehouse 77 Dale Street Manchester, M1 2HG		
Date 09/04/2021 10:19 File 846-04 Corner Building ...	Designed by ThomasC Checked by	
Innovyze	Network 2020.1	

Storage Structures for Storm

Cellular Storage Manhole: 2, DS/PN: 1.001

Invert Level (m) 52.870 Safety Factor 2.0
 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
 Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	12.0	12.0	0.900	0.0	24.8
0.800	12.0	24.8			

Civic Engineers		Page 7
Carvers Warehouse 77 Dale Street Manchester, M1 2HG		
Date 09/04/2021 10:19 File 846-04 Corner Building ...	Designed by ThomasC Checked by	
Innovyze	Network 2020.1	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 1 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR Ratio R 0.352
Region England and Wales Cv (Summer) 0.750
M5-60 (mm) 18.000 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600,
720, 960, 1440, 2160, 2880, 4320, 5760,
7200, 8640, 10080
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Water Level
1.000	600	15 Winter	100	+40%	30/15 Summer			54.180
1.001	2	30 Winter	100	+40%	30/15 Summer			53.507
1.002	3	30 Winter	100	+40%	30/15 Summer			53.467

PN	US/MH Name	Depth (m)	Surcharged Volume (m ³)	Flooded Flow / Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	600	0.910	0.000	4.35		23.0	SURCHARGED	
1.001	2	0.537	0.000	1.28		21	6.8	SURCHARGED
1.002	3	0.497	0.000	0.32		5.0	5.0	SURCHARGED