



Temporary gates to be installed to secure the site throughout construction phases. Gates to be removed upon completion of works and replaced with the proposals where stated

The driveway bridge over the cinder path has been inspected by Curtins Structural Engineers and condemned as structurally unsafe. It is proposed to remove the crown of the bridge and infill the tunnel with compacted material suitable for vehicular traffic.

2 no Temporary gates to be installed to secure the site throughout construction phases. Gates to be removed upon completion of works and replaced with the proposals where stated

Notes:
Drawings are based on survey data and may not accurately represent what is physically present.

Do not scale from this drawing. All dimensions are to be verified on site before proceeding with the work.

All dimensions are in millimeters unless noted otherwise.

Purcell shall be notified in writing of any discrepancies.


Key Plan
not to scale

P01	21/04/21	For Planning
REV	DATE	DESCRIPTION

CLIENT
Colin Shenton

PROJECT
Cuerden Hall, Chorley

JOB NUMBER
240729



TITLE
Location Plan

SIZE	SCALE	LAST REVISED	DRAWN	CHECKED
A1L	As Shown	21/04/2021	ZB	

REV **SUITABILITY/REASON FOR ISSUE**
P01 **S04 - For Planning**

DRAWING NUMBER
240729-PUR-00-XX-DR-A-1000