

Pat Krawczyk

From: Helen Frith
Sent: 07 June 2021 09:14
To: Pat Krawczyk
Subject: RE: CHE/21/00407/FUL

Hi pat,

We need existing and proposed block plans to 1:500
Existing and proposed sections to scale
Elevations – existing and proposed of the retaining wall
FRA required

Thanks

Helen

From: Pat Krawczyk <Pat.Krawczyk@Chesterfield.gov.uk>
Sent: 06 June 2021 08:08
To: Helen Frith <Helen.Frith@Chesterfield.gov.uk>
Subject: CHE/21/00407/FUL

Morning Helen

Could you have a look at the above application please to see if you think we have enough information for validation?
I'm not sure if we need better section drawings for the wall. The submitted one has no scale. The site is also in
Flood Zone 2 – does it need a FRA?

Thank you

Pat