

## PROPOSED EXTERNAL LIGHTING PROPOSALS.

STATEMENT: THE EXTERNAL LIGHTING DESIGN IS TO PROVIDE LOW LEVEL ILLUMINATION AROUND THE PARKING AREAS AND FOOTWAY, THUS PREVENTING GLARE SPILL AND TRESPASS OUT WITH THE SITE AREA.

THE GENERAL LIGHTING ARRANGEMENT IS SPLIT IN TO THREE TYPES; TYPE A WILL BE LOW LEVEL BOLLARDS AROUND THE PARKING AREAS, TYPE B WILL BE BUILDING UNDER SOFFIT LIGHTING AND TYPE C WILL BE BUILDING FACE FIXED DOWN LIGHTERS DETAILED AS FOLLOWS.

TYPE A: LOW LEVEL ENERGY EFFICIENT LED 1100MM HIGH RESIN BOLLARD REF: ASBAC LIGHTING, SAURA 1100 10W LED GX53.

TYPE B: ENERGY EFFICIENT RESIN LED DOWN LIGHTER REF: ASBAC LIGHTING, FRANCA 90, 3.5W LED GU10

TYPE C: ENERGY EFFICIENT RESIN LED WALL MOUNTED AND ANGLED OPAL DIFFUSED LIGHT REF: ASBAC LIGHTING, GERMANA 20W LED GX53

LIGHTING WILL BE CONTROLLED VIA PHOTO CELLS WITH TIMED OVERRUN WITH BACKGROUND / SECURITY LIGHTING BEING PROVIDED OUT WITH BUSINESS TRADING HOURS.

ALL DIMENSIONS IN MILLIMETRES FIGURED DIMENSIONS ONLY TO BE USED FROM THIS DRAWING ONLY UNLESS STATED OTHERWISE READ IN CONJUNCTION WITH ENGINEERS DRAWINGS AND SPECIFICATION ALL SIZES TO BE CHECKED ON SITE BY CONTRACTOR PRIOR TO ORDERING MATERIALS THIS DRAWING IS COPYRIGHT PLANNING REVISION DESCRIPTION DATE UPDATED FOR PLANNING ISSUE: CLIENT INFORMATION UPDATED UPDATED FOR PLANNING ISSUE: CLIENT INFORMATION ADDED ANNOTATIONS ADDED & AMENDED 30.03.20 28.05.21  $\geq$ NOTE: READ IN CONJUNCTION WITH STEWART ASSOCIATES DRAWINGS NO'S 1934 / P01 TO 1934 / P07 INCLUDING DESIGN STATEMENT DOCUMENT NO. 1934 / P06. STEWART ASSOCIATES Architects & Development Consultants THE STUDIO 9 WATERSIDE STREET LARGS ■読読回 AYRSHIRE tel : 01475 670033 fax : 01475 673103 email:info@stewart-associates TLE PROPOSED GARDEN CENTRE & RESTAURANT, SITE NORTH OF FAIRLIE BOWLING CLUB DAVID CASTELVECCHI DRAWING EXTERNAL LIGHTING LAYOUT S C A L E 1:250 AT A1 DATE 29.10.19 CHECKED DRAWN JM UMBER 1934 / P07 B

- EXISTING BURN AND 3M SLOPE EITHER SIDE RETAINED AS EXISTING