

ASHP - Sound Power Level

1. Sound power level (dB)	65
2. Sound pressure level (dB)	<i>Q8 - "Three Reflective Surfaces"</i>
3. Distance from heat pump to assessment position (meters)	10
4. dB Distance Reduction	-22
5. Barriers Between heat pump and assessment position	<i>Barrier (no view)</i>
6. Sound pressure level @ assessment position	33
7. Background noise level (dB)	40
8. Differential between 6. & 7.	7
9. Decibel Correction (dB)	40.8
10. Final Result (dB)	✔ 41.0
	<u>Pass</u>