Summary of Results

Return Period (years)	100
Storm Duration (mins)	30
Profile Type	Winter
Margin for Flood Risk warning (mm)	300
Analysis Time Step	2.5 second increment (extended)
DTS Status	ON
DVD Status	OFF
Inertia Status	OFF

PN	Water Lev. (m)	Surcharged Depth (m)	Flooded Vol (m^3)	Flow/ Capacity	Overflow (l/s)	Pipe Flow (l/s)	Status
1.000	16.272	0.047	0.000	0.36	0.0	11.4	SURCH'ED
1.001	16.279	0.140	0.000	0.21	0.0	40.9	SURCH'ED
1.002	16.276	0.173	0.000	0.16	0.0	40.5	SURCH'ED
1.003	16.281	0.236	0.000	0.24	0.0	47.0	SURCH'ED
1.004	16.714	1.005	0.000	0.08	0.0	5.0	SURCH'ED
1.005	15.390	-0.245	0.000	0.08	0.0	5.0	O K
1.006	15.259	-0.236	0.000	0.10	0.0	5.0	O K

©1982-2008 Micro Drainage