

From:Planning
Subject:FW: 21/00809/FUL - Invalid planning application letter

-----Original Message-----

From: Sam Cheshire
Sent: 22 July 2021 09:49
To: Planning
Subject: RE: 21/00809/FUL - Invalid planning application letter

This email is from an external email address Do not click any links or open attachments unless you know the content is safe.

Never disclose your user details or password to anyone.

Hi planning admin team,

The ground floor levels of the extension will be no lower than existing floor levels and flood measures to be considered as appropriate, including raising of sockets from ground level by 300mm.

Regards,

Sam Cheshire

CFM Consultants Ltd,