

Broomgrove Lodge  
13 Broomgrove Road  
Sheffield S10 2LZ

BGC  
Pulborough Garden Centre  
Car Park



Date 03/07/2021  
File Tank.SRCX

Designed by PSA  
Checked by

XP Solutions

Source Control 2020.1

Summary of Results for 100 year Return Period (+40%)

<b>Storm Event</b>	<b>Max Level (m)</b>	<b>Max Depth (m)</b>	<b>Max Control (l/s)</b>	<b>Max Volume (m³)</b>	<b>Status</b>
15 min Summer	8.031	0.281	2.5	91.2	O K
30 min Summer	8.126	0.376	2.5	122.1	O K
60 min Summer	8.226	0.476	2.5	154.8	O K
120 min Summer	8.322	0.572	2.5	186.0	O K
180 min Summer	8.369	0.619	2.5	201.1	O K
240 min Summer	8.395	0.645	2.5	209.6	O K
360 min Summer	8.424	0.674	2.5	219.0	O K
480 min Summer	8.433	0.683	2.5	222.0	O K
600 min Summer	8.432	0.682	2.5	221.6	O K
720 min Summer	8.424	0.674	2.5	218.9	O K
960 min Summer	8.402	0.652	2.5	211.8	O K
1440 min Summer	8.367	0.617	2.5	200.6	O K
2160 min Summer	8.322	0.572	2.5	185.8	O K
2880 min Summer	8.276	0.526	2.5	171.0	O K
4320 min Summer	8.172	0.422	2.5	137.3	O K
5760 min Summer	8.078	0.328	2.5	106.5	O K
7200 min Summer	8.001	0.251	2.5	81.4	O K
8640 min Summer	7.938	0.188	2.5	60.9	O K
10080 min Summer	7.888	0.138	2.5	44.8	O K
15 min Winter	8.065	0.315	2.5	102.5	O K
30 min Winter	8.173	0.423	2.5	137.4	O K

<b>Storm Event</b>	<b>Rain (mm/hr)</b>	<b>Flooded Volume (m³)</b>	<b>Discharge Volume (m³)</b>	<b>Time-Peak (mins)</b>
15 min Summer	130.386	0.0	93.7	19
30 min Summer	88.061	0.0	126.6	34
60 min Summer	56.713	0.0	163.1	64
120 min Summer	35.186	0.0	202.6	124
180 min Summer	26.170	0.0	225.9	182
240 min Summer	21.081	0.0	242.7	242
360 min Summer	15.557	0.0	268.6	362
480 min Summer	12.518	0.0	288.2	482
600 min Summer	10.566	0.0	304.1	600
720 min Summer	9.195	0.0	317.7	720
960 min Summer	7.376	0.0	339.7	830
1440 min Summer	5.395	0.0	372.8	1084
2160 min Summer	3.937	0.0	408.2	1492
2880 min Summer	3.144	0.0	434.7	1908
4320 min Summer	2.285	0.0	473.7	2720
5760 min Summer	1.821	0.0	503.2	3456
7200 min Summer	1.529	0.0	528.1	4176
8640 min Summer	1.325	0.0	549.2	4848
10080 min Summer	1.174	0.0	568.4	5544
15 min Winter	130.386	0.0	105.0	19
30 min Winter	88.061	0.0	141.8	33

Broomgrove Lodge  
13 Broomgrove Road  
Sheffield S10 2LZ

BGC  
Pulborough Garden Centre  
Car Park



Date 03/07/2021  
File Tank.SRCX

Designed by PSA  
Checked by

XP Solutions

Source Control 2020.1

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m³)	Status
60 min Winter	8.287	0.537	2.5	174.4	O K
120 min Winter	8.397	0.647	2.5	210.4	O K
180 min Winter	8.453	0.703	2.5	228.4	O K
240 min Winter	8.485	0.735	2.5	238.8	O K
360 min Winter	8.523	0.773	2.5	251.3	O K
480 min Winter	8.540	0.790	2.5	256.9	O K
600 min Winter	8.545	0.795	2.5	258.5	O K
720 min Winter	8.543	0.793	2.5	257.7	O K
960 min Winter	8.525	0.775	2.5	251.8	O K
1440 min Winter	8.473	0.723	2.5	235.0	O K
2160 min Winter	8.411	0.661	2.5	214.9	O K
2880 min Winter	8.345	0.595	2.5	193.2	O K
4320 min Winter	8.190	0.440	2.5	143.1	O K
5760 min Winter	8.042	0.292	2.5	94.9	O K
7200 min Winter	7.934	0.184	2.5	59.7	O K
8640 min Winter	7.857	0.107	2.5	34.7	O K
10080 min Winter	7.805	0.055	2.4	18.0	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
60 min Winter	56.713	0.0	182.6	62
120 min Winter	35.186	0.0	226.7	122
180 min Winter	26.170	0.0	253.1	180
240 min Winter	21.081	0.0	271.9	238
360 min Winter	15.557	0.0	300.8	354
480 min Winter	12.518	0.0	323.0	468
600 min Winter	10.566	0.0	340.6	582
720 min Winter	9.195	0.0	355.8	692
960 min Winter	7.376	0.0	380.5	904
1440 min Winter	5.395	0.0	392.5	1140
2160 min Winter	3.937	0.0	457.0	1604
2880 min Winter	3.144	0.0	486.6	2076
4320 min Winter	2.285	0.0	530.4	2940
5760 min Winter	1.821	0.0	563.9	3640
7200 min Winter	1.529	0.0	591.6	4328
8640 min Winter	1.325	0.0	615.3	4936
10080 min Winter	1.174	0.0	636.4	5552

Broomgrove Lodge 13 Broomgrove Road Sheffield S10 2LZ	BGC Pulborough Garden Centre Car Park
---	---



Date 03/07/2021 File Tank.SRCX	Designed by PSA Checked by
-----------------------------------	-------------------------------

XP Solutions	Source Control 2020.1
--------------	-----------------------


Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.000	Shortest Storm (mins)	15
Ratio R	0.339	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.384

<b>Time (mins)</b>	<b>Area</b>
<b>From: To:</b>	<b>(ha)</b>
0	4 0.384

HCD Limited		Page 4
Broomgrove Lodge 13 Broomgrove Road Sheffield S10 2LZ	BGC Pulborough Garden Centre Car Park	
Date 03/07/2021 File Tank.SRCX	Designed by PSA Checked by	

XP Solutions Source Control 2020.1

Model Details

Storage is Online Cover Level (m) 9.000

Tank or Pond Structure

Invert Level (m) 7.750

Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )
0.000	325.0	0.800	325.0

Hydro-Brake® Optimum Outflow Control

Unit Reference	MD-SHE-0077-2500-0900-2500
Design Head (m)	0.900
Design Flow (l/s)	2.5
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	77
Invert Level (m)	7.650
Minimum Outlet Pipe Diameter (mm)	100
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.900	2.5	Kick-Flo®	0.568	2.0
Flush-Flo™	0.271	2.5	Mean Flow over Head Range	-	2.2

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	2.1	1.200	2.9	3.000	4.4	7.000	6.5
0.200	2.5	1.400	3.1	3.500	4.7	7.500	6.7
0.300	2.5	1.600	3.3	4.000	5.0	8.000	6.9
0.400	2.4	1.800	3.4	4.500	5.3	8.500	7.1
0.500	2.3	2.000	3.6	5.000	5.5	9.000	7.3
0.600	2.1	2.200	3.8	5.500	5.8	9.500	7.5
0.800	2.4	2.400	3.9	6.000	6.0		
1.000	2.6	2.600	4.1	6.500	6.3		