

Your ref:		Please reply to:	Mr Anthony Perera
Our ref:	21/04662/FULL	Tel No:	07866034072
		Fee Queries:	0207 641 6500;
		Email:	planningreception@westminster.gov.uk;
Studio Octopi Romer-Lee Studio Octopi 1C Burrows Mews London SE1 8LD		Incomplete Applications Development Planning City of Westminster PO Box 732 Redhill, RH1 9FL	
		15 July 2021	

Dear Sir / Madam

TOWN AND COUNTRY PLANNING ACT 1990
 PLANNING (LISTED BUILDINGS & CONSERVATION AREAS) ACT 1990

Address: 82 St John's Wood High Street, London, NW8 7SH

Proposal: New shopfront window and door to street including replacement and ventilation to rear elevation.

Thank you for your application received on 9 July 2021. I am writing to inform you that your application is incomplete for the following reason(s):

1 Please submit a detailed acoustic report.

The report is to include the following information:

* The location of the nearest sensitive premises that may be affected by noise from the proposed plant or activity. Sensitive use in this context includes residential, hospitals, hotels, hostels, educational establishments, concert halls, theatres, but is not exhaustively limited to these use types. Indicate the distance of the window(s) from the source in metres.

* The proposed operational hours of the plant/activity, plant type, number and locations.

* The measured Ambient noise level (L_{aeq}) for the 16 hours daytime and 8 hours night time (If plant to operate at night) to assess which planning condition applies.

* The representative lowest background noise level assessment (LA₉₀ 15 minutes) over the proposed hours of operation including the time, date and weather conditions, instrumentation and calibration, noise sampling locations and a copy of the noise survey data, (Graphical & numerical).

* Manufacturers Specifications of plant and/or proposed noise levels of internal activity in Octave or 1/3 octave band format.

* Calculations for the predicted noise level 1 metre from the window of the nearest sensitive property including distance, directionality and screening effects.

* You will need to demonstrate that the predicted noise level outside the most affected window will comply with the limits stated in our standard conditions. As a guideline these limits are normally 10dB below the lowest background LA90 (15mins). However you will need to refer to policy ENV 7 in the Unitary Development Plan, which may require correction penalties for tonality or intermittency.

* Include any proposed attenuation measures and details of noise reductions achieved.

Additionally, it is recommended that reference be made to BS 8233:2014, which contains guidance for commercial design criteria.

You may wish to contact Environmental Health directly (Tel 020 7641 2000) to discuss technical issues relating to the submission of an acoustic report.

2 *Please collate all requested information in a single submission, and send to planningreception@westminster.gov.uk. Sending your documents individually will not speed up the process. Please do not upload to the planning portal as this causes duplication and may delay the processing of your application. Thank you.*

Please forward this information to the above email address by **12 August 2021**. Please do not forward the requested information separately, as your application will only be progressed when ALL requested information has been received. Please send revised/new information to the email address, not via the planning portal.

The description of development may have been changed to better reflect the proposed works, if you do not agree that this accurately reflects your proposals, please provide an amended description of development when you respond to the above.

If we do not receive this information within four weeks of this notification we shall take no further action on your application. If you require longer than four weeks to submit the revised information, please contact us.

If you'd like to make a payment, please call: 020 7641 6500, or for general enquiries call: 07890380503. **Please note, for queries relating to this case, please refer to the officer dealing with your case: details at top of the letter.**

Yours faithfully

Mr Anthony Perera

Mr Anthony Perera

Note - Please read our Privacy Notice online <https://www.westminster.gov.uk/privacy-notice-planning>