No. C0452

Fire Suppression

CERTIFICATE

This is to certify that Amsco Fire Ltd. has designed & installed a fire suppression system to the required standard at :

Flat 3, 87A St James Street, Brighton, BN2 1TP

Details:

Design standard:	BS9251:2014
Design risk:	2 Head Domestic
Head Type:	68 Degree, Pendant
Head info:	Viking 488, 34.9Lpm @ 0.5bar
No. Heads	2
Max coverage:	15 sq. mtrs.
Spec agreed AHJ?:	Yes

Deviations:

Partial System

Coverage

Kitchen

Water supply

2 x 450 Litre Flat tank

Pump

Griffen B230–25/85 Model YD5M2 - 60B Volts 230 Serial No.2016 11496

Installed by :

Amsco Fire Ltd
Unit G9,Atlas Business Park
Rye Harbour Road, Rye
East Sussex, TN31 7TE
Tel: 01424 813131 www.amsco.co.uk

Client : Izzet Gunsel

Designed by : Kaj Haines

Date commissioned : 16th January 2018

Engineer : PL

Signed : [redacted]

Managing Director

Amsco Fire Ltd

AMSCO FIRE LTD AMSCO Reg. No. 7463116