



DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with British Standard BS 7671 - Requirements for Electrical Installations

Certificate Reference:

2020-2497

1 DETAILS OF THE CLIENT

Client:

Address:

2 DETAILS AND EXTENT OF THE INSTALLATION

Installation Address: Ground Floor Flat , 181A Noel Road, London, W3 0JJ

Extent of the installation covered by this certificate:

New Build

The installation is: New installation Addition to an existing installation N/A Alteration to an existing installation N/A

3 COMMENTS ON EXISTING INSTALLATION

All New Build.

4 NEXT INSPECTION

I RECOMMEND that this installation is further inspected and tested after an interval of not more than:

5 Years

5 TEST INSTRUMENTS

Details of Test Instruments used (state serial and/or asset numbers):

Multi-functional:	1730	Earth electrode resistance:	N/A
Insulation resistance:	1730	Earth fault loop impedance:	1730
Continuity:	1730	RCD:	1730

6 DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I/We being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671:2008, amended to 2015 except for the departures, if any, detailed as follows.

Details of departures from BS 7671, as amended (Regulations 120.3, 133.5):

None

Details of permitted exceptions (Regulations 411.3.3):

Risk assessment attached

N/A

None

The extent of liability of the signatory/signatories is limited to the work described above as the subject of this certificate.

For the DESIGN, the CONSTRUCTION, and the INSPECTION AND TESTING of the installation:

Name: BILL BIRDI Position: Senior Engineer Signature: *Birdi* Date: 31/10/2015

7 DETAILS OF THE ELECTRICAL CONTRACTOR

Trading Title: Paaji Ltd (Napit Registered)

Address: 70 Keats Way
West Drayton

Registration Number (if applicable): 115 38

Telephone Number: 07932174467

Postcode: UB7 9DU

8 SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS						
Earthing Arrangements	Number and Type of Live Conductors			Nature of Supply Parameters		Supply Protective Device
TN-S <input checked="" type="checkbox"/>	1-phase (2 wire): <input checked="" type="checkbox"/>	1-phase (3 wire): N/A	N/A	Nominal voltage(s): U: 240 V U ₀ : 230 V	BS(EN): Red Head	
TN-C-S <input type="checkbox"/>	3-phase (3 wire): N/A	3-phase (4 wire): N/A	N/A	Nominal frequency, f: 50 Hz	Type:	
TT <input type="checkbox"/>	Other: N/A			Prospective fault current, I _{pf} : 0.92 kA	Rated current:	A
	Confirmation of supply polarity: <input checked="" type="checkbox"/>			External earth fault loop impedance, Z _e : 0.23 Ω	Short-circuit capacity:	kA

9 PARTICULARS OF INSTALLATION REFERRED TO IN THE CERTIFICATE						
Means of Earthing		Details of Installation Earth Electrode (where applicable)				
Distributor's facility: <input checked="" type="checkbox"/>	Type: N/A	Location: N/A				
Installation earth electrode: N/A	Resistance to Earth: N/A Ω	Method of measurement: N/A				
Maximum Demand (Load): 60 Amps	Protective measure(s) against electric shock: ADS	Measured Z _e : 0.20 Ω				
Main Switch / Switch-Fuse / Circuit-Breaker / RCD Type		Supply conductors material: Copper		If RCD main switch:		
BS(EN): 60947-3 Isolator	Current rating: 100 A	Supply conductors csa: 25 mm ²		Rated residual operating current (I _n):	N/A mA	
Number of poles: 2	Fuse/device rating or setting: Lim A			Rated time delay:	N/A ms	
	Voltage rating: 240 V			Measured operating time (I _n):	N/A ms	
Earthing and Protective Bonding Conductors			Bonding of extraneous-conductive parts			
Earthing conductor		Connection/continuity verified: <input checked="" type="checkbox"/>		To water installation pipes: N/A	To gas installation pipes: <input checked="" type="checkbox"/>	
Conductor material: Copper	csa: 16 mm ²			To oil installation pipes:		
Main protective bonding conductors		Connection/continuity verified: <input checked="" type="checkbox"/>		To structural steel:	N/A	
Conductor material: Copper	csa: 10 mm ²					

10 SCHEDULE OF ITEMS INSPECTED		
Item	Description	Outcome
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT	
1.1	Condition of service cable	<input checked="" type="checkbox"/>
1.2	Condition of service head	<input checked="" type="checkbox"/>
1.3	Condition of distributor's earthing arrangement	<input checked="" type="checkbox"/>
1.4	Condition of tails - Distributor/Consumer	<input checked="" type="checkbox"/>
1.5	Condition of metering equipment	<input checked="" type="checkbox"/>
1.6	Condition of isolator (where present)	N/A
2.0	PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY	
3.1	Presence and adequacy of earthing and protective bonding arrangements:	
3.1.1	Installation earth electrode (where applicable) (542.1.2.3)	N/A
3.1.2	Earthing conductor and connections including accessibility (542.3; 543.3.2)	<input checked="" type="checkbox"/>
3.1.3	Main protective bonding conductors and connections, including accessibility (411.3.1.2; 543.3.2)	<input checked="" type="checkbox"/>
3.1.4	Provision of safety electrical earthing / bonding labels at all appropriate locations (514.13)	<input checked="" type="checkbox"/>
3.1.5	RCD(s) provided for fault protection (411.4.9; 411.5.3)	<input checked="" type="checkbox"/>
4.0	BASIC PROTECTION	
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:	
4.1.1	Insulation of live parts e.g. conductors completely covered with durable insulation materials (416.1)	<input checked="" type="checkbox"/>
4.1.2	Barriers or enclosures e.g. correct IP rating (416.2)	<input checked="" type="checkbox"/>

11 SCHEDULE OF ITEMS INSPECTED

Item	Description	Outcome
5.0	ADDITIONAL PROTECTION	
5.1	Presence and effectiveness of additional protection methods:	
5.1.1	RCD(s) not exceeding 30mA operating current (415.1; Part 7), see Item 8.14 of this schedule	✓
5.1.2	Supplementary bonding (415.2; Part 7)	N/A
6.0	OTHER METHODS OF PROTECTION	
6.1	Presence and effectiveness of methods which give both basic and fault protection:	
6.1.1	SELV systems including the source and associated circuits (Section 414)	N/A
6.1.2	PELV systems, including the source and associated circuits (Section 414)	N/A
6.1.3	Double or reinforced insulation i.e. Class II or equivalent equipment and associated circuits (Section 412)	✓
6.1.4	Electrical separation for one item or equipment e.g. shaver supply unit (Section 413)	✓
7.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)	
7.1	Adequacy of access and working space for items of electrical equipment including switchgear (132.12)	✓
7.2	Presence of linked main switch(s) (537.1.4; 537.1.5; 537.1.6)	N/A
7.3	Isolators, for every circuit or group of circuits and all items of equipment (537.2)	✓
7.4	Suitability of enclosure(s) for IP and fire ratings (416.2; 421.1.6; 421.1.201)	✓
7.5	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.11)	✓
7.6	Confirmation that ALL conductor connections are correctly located in terminals and are tight and secure (526.1)	✓
7.7	Avoidance of heating affects where cables enter ferromagnetic enclosures e.g. steel (521.5)	N/A
7.8	Selection of correct type and ratings or circuit protective devices for overcurrent and fault protection (411.3.2; 411.4, .5, .6; Sections 432, 433)	✓
7.9	Presence of appropriate circuit charts, warning and other notices:	
7.9.1	Provision of circuit charts/schedules or equivalent forms of information (514.9)	✓
7.9.2	Warning notice of method of isolation where live parts not capable of being isolated by a single device (514.11)	N/A
7.9.3	Periodic inspection and testing notice (514.12.1)	✓
7.9.4	RCD quarterly test notice; where required (514.12.2)	✓
7.9.5	Warning notice of non-standard (mixed) colours of conductors present (514.14)	✓
7.10	Presence of labels to indicate the purpose of switchgear and protective devices (514.1.1; 514.8)	✓
8.0	CIRCUITS	
8.1	Adequacy of conductors for current-carrying capacity with regard to type and nature of the installation (Section 523)	✓
8.2	Cable installation methods suitable for the location(s) and external influences (Section 522)	✓
8.3	Segregation/separation of Band I (ELV) and Band II (LV) circuits, and electrical and non-electrical services (528)	N/A
8.4	Cables correctly erected and supported throughout including escape routes, with protection against abrasion (Sections 521, 522)	✓
8.5	Provision of fire barriers, sealing arrangements where necessary (527.2)	✓
8.6	Non-sheathed cables enclosed throughout in conduit, ducting or trunking (521.10.1; 526.8)	N/A
8.7	Cables concealed under floors, above ceilings or in wall/partitions, adequately protected against damage (522.6.201, .202, .204)	✓
8.8	Conductors correctly identified by colour, lettering or numbering (Section 514)	✓
8.9	Presence, adequacy and correct termination of protective conductors (411.3.1.1; 543.1)	✓
8.10	Cables and conductors correctly connected, enclosed and with no undue mechanical strain (Section 526)	✓
8.11	No basic insulation of a conductor visible outside enclosure (526.8)	✓
8.12	Single-pole devices for switching or protection in line conductors only (132.14.1; 530.3.2)	✓
8.13	Accessories not damaged, securely fixed, correctly connected, suitable for external influences (134.1.1; 512.2; Section 526)	✓

12 SCHEDULE OF ITEMS INSPECTED

Item	Description	Outcome
8.14	Provision of additional protection by RCD not exceeding 30mA:	
8.14.1	Socket-outlets rated at 20 A or less unless exempt (411.3.3)	✓
8.14.2	Mobile equipment with a current rating not exceeding 32 A for use outdoors (411.3.3)	N/A
8.14.3	Cables concealed in walls at a depth of less than 50 mm (522.6.202, .203)	✓
8.14.4	Cables concealed in walls/partitions containing metal parts regardless of depth (522.6.202; 522.6.203)	✓
8.15	Presence of appropriate devices for isolation and switching correctly located including:	
8.15.1	Means or switching off for mechanical maintenance (537.3)	✓
8.15.2	Emergency switches (537.4)	✓
8.15.3	Functional switches, for control of parts of the installation and current-using equipment (537.5)	✓
8.15.4	Firefighter's switches (537.6)	N/A
9.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	
9.1	Equipment not damaged, securely fixed and suitable for external influences (134.1.1; 416.2; 512.2)	✓
9.2	Provision of overload and/or undervoltage protection e.g. for rotating machines, if required (Sections 445, 552)	N/A
9.3	Installed to minimise the build-up of heat and restrict the spread of fire (421.1.4; 559.4.1)	N/A
9.4	Adequacy of working space. Accessibility to equipment (132.12; 513.1)	N/A
10.0	LOCATION(S) CONTAINING A BATH OR SHOWER (SECTION 701)	
10.1	30 mA RCD protection for all LV circuits, equipment suitable for the zones, supplementary bonding (where required) etc.	✓
10.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A
10.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	✓
10.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)	N/A
10.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3m from Zone 1 (701.512.3)	N/A
10.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	✓
10.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	✓
10.8	Suitability of current-using equipment for particular position within the location (701.55)	✓
11.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS List all other special installations or locations present, if any (Record separately the results of particular inspections)	
11.1	N/A	N/A
11.2	N/A	N/A

13 SCHEDULE OF ITEMS TESTED

Item	Description	Outcome
12.1	External earth fault loop impedance, Z_e	✓
12.2	Installation earth electrode resistance, R_a	N/A
12.3	Continuity of protective conductors	✓
12.4	Continuity of ring final circuit conductors	✓
12.5	Insulation resistance between live conductors	✓
12.6	Insulation resistance between live conductors and earth	✓
12.7	Polarity	✓
12.8	Earth fault loop impedance, Z_s	✓
12.9	Verification of phase sequence	N/A
12.10	Operation of residual current device(s)	✓
12.11	Functional testing of assemblies	✓
12.12	Verification of voltage drop	N/A

All boxes must be completed. 'tick' indicates that an inspection or test was carried out and that the result was satisfactory. 'X' indicates that an inspection or test was carried out and the result is not satisfactory. 'N/A' indicates that an inspection or test was not applicable to the particular installation. 'LIM' indicates that, exceptionally, a limitation agreed with the person ordering the work prevented the inspection or test being carried out.

