

From: PLServices <plservices@eastcambs.gov.uk>
Sent: 08 Sep 2021 04:07:25
To: DMSPlanning@eastcambs.gov.uk
Cc:
Subject: FW: 21/01311/FUL - The Old Store High Street Brinkley
Attachments:

From: Christopher Smith
Sent: 08 September 2021 16:00
To: Rachael Forbes <Rachael.Forbes@eastcambs.gov.uk>
Cc: PLServices <plservices@eastcambs.gov.uk>; Peter Ord <Peter.Ord@eastcambs.gov.uk>
Subject: 21/01311/FUL - The Old Store High Street Brinkley

Hi Rachael,

Proposal: Installation of a Heat Source Air pump with a certified MCS
Company on highway facing garden
Location: The Old Store High Street Brinkley Newmarket
Reference: 21/01311/FUL

Thank you for consulting us on the above application.

There is information submitted which demonstrates the requirements of MCS 20 will be met so I have no issues to raise but would recommend the following condition –

“The specific rated noise level emitted shall not exceed the existing background noise level by more than 5 dB. The free field sound level shall be measured and/or calculated at the boundary of the nearest noise sensitive property. The noise level shall be measured and/or calculated in accordance with BS 4142:2014+A1:2019.

Reason: To safeguard the residential amenity of neighbouring occupiers, in accordance with policy EN2 of the East Cambridgeshire Core Strategy 2009.”

Thanks

Christopher Smith
Environmental Health Technical Officer (Domestic) – MCIEH, Dip (IoA)
East Cambridgeshire District Council
The Grange
Nutholt Lane
Ely
Cambridgeshire
CB7 4EE
01353 665555