

Existing engineering brick treads are generally in good condition and are to be retained as existing and repointed

Gravel to be renewed to align with level of limestone nosings to provide support and prevent further damage and chipping to stone



Existing brick piers and stone dressings in generally good condition. To be retained as existing

Existing limestone nosings generally in reasonable condition. To be retained as existing with localised repointing

EXISTING TERRACE STEPS NO.03- PHOTO WITH REPAIR NOTES

Existing limestone kerb unit retained, straightened and repointed

New blue engineering brick to replace missing unit

Existing engineering brick treads are generally in good condition and are to be retained and repointed

Gravel to be renewed to align with level of paver bricks to provide support and prevent bricks being chipped



New blue engineering brick to replace missing unit

Existing limestone kerb retained, straightened and repointed

EXISTING TERRACE STEPS NO.04- PHOTO WITH REPAIR NOTES

DRAFT FOR  
REVIEW AND  
COMMENT

GENERAL NOTES:

- To be read in conjunction with QQA Heritage, Design Access Statement Outline Scope of Works Document;
- To be read with general location plan 9756-1 P(0)1000 and all structural engineers documents;
- Existing Steps 03: Steps to formal rose gardens formed from 3 treads, with limestone nosings and dressings to 2x brick piers. The steps are generally in good condition, with no evidence of structural cracking or movement. Localised repointing only is required.
- Existing Steps 04: Steps leading to Headmaster's House and garden. The top pair of limestone kerbs require resetting with 2x replacement black engineering bricks where they are missing. Complete repointing is required.



Notes: This drawing is the copyright of Giles Quarme Architects and cannot be printed or re-produced without prior permission. Do not scale. This drawing has been based on survey information provided by On Centre Surveys. All dimensions and setting out must be verified on site before commencement of the work, and any discrepancies notified to the architect. All windows and doors are to fit into existing openings. All dimensions are in millimetres unless stated otherwise.

Project and Project No:	HABERDASHER'S SCHOOL
Title:	EXISTING TERRACE STEPS 03-04 - REPAIRS

Drawing No:	9756-1 P(0)1002
Date:	May 2021
Scale:	1:500, 1:20 1:50@A3
Revision:	-
Drawn:	NCB
Checked:	GQ

GILES QUARME ARCHITECTS <i>(Chartered Architects)</i>	Tel: (020) 7582 0748 Fax: (020) 7793 8807 E-mail: mail@quarme.com
7 BISHOP'S TERRACE LONDON SE11 4UE	