

Mitchell, Gillian

From: planning.comments@york.gov.uk
Subject: FW: Planning Application Consultation 21/02304/FUL at The Granary Old Carlton Farm

From: Planning Consultation Mailin <
Sent: 18 November 2021 09:05
To: Bell, Victoria <Victoria.Bell@york.gov.uk>
Subject: RE: Planning Application Consultation 21/02304/FUL at The Granary Old Carlton Farm

Morning Victoria,

Thanks for consultation letter and we have no observation comments to make as foul water is draining to new private package treatment plant that replaces existing septic tank that serves the property and surface water shown to soakaway (existing) in garden.

Kind regards

Jim McGlade
Development Control Agent
Developer Services
Pre Development Team