

Cornwall Council Planning & Regeneration,
Cornwall Council
Room 245
New County Hall
Truro
TR1 3AY

Lostwithiel Road
Bodmin
Cornwall
PL31 1DE



Our ref: CE4151376

Date
22 November 2021

Dear Sir or Madam

OHL sect 37 Exemption Electricity at Work Act 1989

Proposed overhead pole work at St Eval, TR8 4DN

Please find enclosed a copy of the Company's drawing number S4151376 which illustrates our proposed works on site to stand 12 new poles with 5 associated stay wires in the highway verge to support 1006m of overhead 11kv conductors from which WPD will take an underground cable into private land to a new pole with a lazy leg which will support a three phase transformer. From this transformer an underground cable will provide a new connection to a single customer.

As this is considered to be a 'Permitted Development' under class B of part 15 of the town and country planning permitted development, England order 2015 it is not our intention to make a formal application for Planning Permission.

If I do not receive a response from you within 6 weeks (6/1/22), I will presume that you have no objections.

Yours faithfully

Clare Eddy

Mrs C Eddy
Estates Specialist