

Quotations/SGN <quotations@sgn.co.uk>

Thu 11/11/2021 10:56

kelvingrove pic.tif

561 KB



Hi Louise,

GCC have requested the following information:

- **Diameter** of the pipe? – **63mm PE in footpath 1" steel above ground**
- What the pipe is made of? - **Plastic in the footpath Steel above ground**
- A diagram of the pipe to be installed as low as possible and to run up the lower frame of the ceiling within the close – **See attached pictures**

Can you also please clarify the following:

- Who made the decision that the variation was to be amended?
- What is the reason for the change?

Stuart / Laura ,

Are you able to answer the last 2 questions.

**Kind Regards**

**Richard Price**

**Design Assistant**

T: 0800 912 1700

E: [quotations@sgn.co.uk](mailto:quotations@sgn.co.uk)

SGN Connections, Axis House, 5 Lonehead Drive, Newbridge, Edinburgh, EH28 8TG

[sgn.co.uk](http://sgn.co.uk)

Find us on [Facebook](#) and follow us on Twitter: [@SGNgas](#)

