


All works to comply with relevant Codes of Practice and British Standards. No work should commence until local authority has issued a building regulation approval. No drainage or services other than those shown appear to pass under the proposed work however if any found on excavation or otherwise to be carried out to satisfaction of relevant authority. All drain positions are approximate and only refer to survey of property subject of application. It is advised contact Colin Luther Associates for confirmation.



SIDE ELEVATION FRONT ELEVATION



REAR ELEVATION

150mm concrete foundations to minimum depth of 1m or as agreed on site by L.A. and to suit ground conditions where walls are within 1m of drains foundations to be taken down to invert level of drain or as agreed with L.A. Depth of foundations to be sufficient so as not to exert additional ground pressure on existing drains.

Ground floor finish as agreed with client on 75mm cement screed reinforced with chicken wire over 90mm thick Celotex insulation on 150mm site concrete with 1200 G d.p.c. under to be contiguous with existing house and new wall d.p.c. on 50mm sand bedding on 150mm hardcore bed any existing floor vents covered by new floors to be ducted through to external air with 100mm diameter underground pvc pipes or as agreed with L.A.

First floor 21mm flooring grade T & G chipboard over joists sizes and crs. as per plan 100mm Rockwool mineral quilt (10kg/m³ cub) laid between joists. 12.5mm plasterboard to U/S T & G boarding to shower and bath room floors to be water resistant to grade P5 with B S stamp on upper surface. Ceilings to be taped and sealed including services passing through.

Walls all internal surfaces finished with 12.5mm plasterboard on dabs d.p.c. to cills. Reveals of all openings in cavity walls to be closed with patent insulated cavity closers, where cavity is bridged provide stepped d.p.c horizontal d.p.c to be minimum 150mm above adjoining external ground level. Seal cavity at top of walls external render to have waterproof additive and not to bridge the horizontal d.p.c. New horizontal d.p.c to be contiguous with existing d.p.c.

300mm cavity wall of two skins 100mm Celcon blocks with stainless steel wall ties at 450mm vertical and 750mm horizontal crs. Staggered cavity fill of 75mm CW4000 insulation secured with wall clips to inner skin as manufacturers recommendations, walls rendered externally render not to bridge horizontal d.p.c. where access is not available to render externally wall outer skin to be brickwork.

220mm Celcon blockwork rendered externally reinforced with a m. l. every third course and lined internally with 50mm Celotex FR4000 in accordance with manufacturers recommendations with joints sealed 50x25mm treated battens at 600 crs fixed over face with 12.5mm plasterboard.

220mm blockwork lined internally with 60mm Celotex FR4000 in accordance with manufacturers recommendations with joints sealed 50x25mm treated battens at 600 crs fixed over face with 12.5mm plasterboard.

Flat roof - cold deck construction to be covered with 12mm thick mineral chippings bedded in hot bitumen over 3 layers of roofing felt complying with B S 747 all set in hot bitumen on 18mm marine ply or boarding over firing to provide fall 1 in 60. 50x50mm cross battens at 400mm crs. To provide cross ventilation to roof space over joists sizes and crs. As per plan 200mm Celotex XFR4000 insulation laid between joists 1000 G polythene fixed to underside of joists as vapour barrier. 9.5mm plasterboard ceiling set with plaster, alternatively use 9.5mm Gyproc Duplex plasterboard. Form upstands and weather over tops of fascia of 150x25mm T & G boarding roof ventilated in accordance with C.P. 144 - 25mm air space between fascia and wall. Where abutting existing walls felt taken up over lifting felt minimum 150mm above roof level and weathered in chase in wall. Alternative insulation 150mm Celotex FR4000 between joists. 50mm Celotex FR4000 under joists. Joints taped.

Flat roof - warm deck construction to be covered with 12mm thick mineral chippings bedded in hot bitumen over 3 layers of roofing felt complying with B S 747 all set in hot bitumen over 140mm Celotex TC3000 roof board laid and joined to manufacturer recommendations on firings to provide fall of 1 in 60 on joists sizes and crs. as per plan. 9.5mm plasterboard ceiling set with plaster no ventilation provided to roof space.

All timber exposed and built into walls to be treated with wood preservative in accordance with C.P. 55 timber in roof void to be pressure impregnated with preservative.

Roofwater Drainage by 100mm Supa sleeve drain pipes at minimum fall 1 in 40 bedded on 100mm concrete or 100mm underground pvc pipes on pea shingle may be used if agreed with L.A. drains to run to soakways minimum 5m from buildings and constructed in stain brickwork size and depth to be agreed with L.A.

Roof beams to be encased with 2 layers of 9.5mm plasterboard fixed with 1.6mm wire binding at 100mm pitch and set with 7mm plaster beams to rest on concrete padstones at each end. Minimum end bearing for beams 225mm or agreed with L.A. twin steel beams to be diaphragm bolted together with spacers at 800mm crs, steel beams encased in concrete to be wrapped in 6mm dia. M.S. links at 225mm horizontal centres and encased in minimum 50mm concrete cover to all surfaces.

Lintels and vertical concrete to external walls that patent restraints straps at minimum 1.8m crs up to first floor and at max 1.2m crs above first floor level. King of straps to joists as per manufacturers recommendations according to exposure rating and to conform with BS CP112.

Sanitary fittings to run in single stack to relevant s.v.p. bath beam shower bidet and sink all to be fixed with 75mm deep seal traps. Waste pipes sizes as indicated on plan; all to have cleaning eyes at any change of direction no waste pipe to connect to s.v.p. within areas of 200mm of centre line of w.c. branch connections.

Exhaust ventilation and background ventilation of 8000 mm sq to all new or extended habitable rooms by trickle vent 1.7m above F.F.L. install extractor fan to new and extended kitchen, extractor fan to provide extract rate of 60 litres/sec, alternatively provide cooler hood extractor to provide extract rate of 30 litres/sec install extractor fan to new bathroom or shower room, extractor fan to provide extract rate of 15 litres/sec. new utility extractor to provide extract rate of 30 litres/sec. provide Background ventilation of 4000mm sq to kitchen, bathroom, shower room and utility room. All habitable rooms to be provided with windows supplying an open able ventilation area of at least 5% of the room, min. of 1.75m above floor level.

Glassing to new and replacement doors and adjacent sideights up to height of 1.5m above F.F.L. to be in safety glass to comply with B S 6206 Class C. All new window and external doors to be double glazed and to have a 'U' value of 1.2 W/m² K.

All existing lintels, beams, foundations and roof structures affected by changes in loading conditions are to be exposed for inspection and any remedial works found necessary to be undertaken by the contractor before commencing any new works this to be in consultation and agreement of the local authority building control. All electrical work required to meet the requirements of Part P (electrical safety) must be designed, installed, inspected and tested by a person competent to do so. Prior to completion the Council should be satisfied that Part P has been complied with. This may require an appropriate B.S. 7871 installation certificate to be issued for the work by a person competent to do so.

Main generated smoke detector to BS5839 - Part 6 (with battery back up) to be installed at the ground and first floor landings. Fire alarm to have an installation and commissioning certificate and the building occupier should be provided with information on the use of the equipment and on the maintenance. This should include the manufacturers instructions.

Heating system where existing heating system is extend all new radiators to be fitted with thermostatic valves. If existing boiler is to be replaced new boiler to have a SEDBUK rating of 86%, plus all work to be carried out by a Gas Safe registered engineer.

Your attention is drawn to the following which forms part of the contract between you, the Customer, and Colin Luther Associates Limited (the Company).


1. To enable services to be provided at the most competitive price possible, the Customer and the Company agree that the Company's liability under and in connection with this agreement shall not exceed AND WE DRAM 2% the price of the drawings and specifications for the work the Company has not conducted AND WE DRAM 2% the price of the drawings and specifications for the work the Company has not conducted AND WE DRAM 2% the price of the drawings and specifications for the work the Company has not conducted.

2. The CUSTOMER'S ATTENTION IS PARTICULAR TO THE LIMITATION OF LIABILITY PROVISIONS BELOW. The Company shall not be liable for any loss or damage (whether for loss of profit, loss of business or otherwise), costs, expenses or other claims for consequential compensation whatsoever and however caused which arise out of or in connection with the agreement and provision of services to the Customer.


3. The Company shall have no liability to the Customer for any loss, damage, costs, expenses or other claims for consequential compensation whatsoever and however caused which arise out of or in connection with the agreement and provision of services to the Customer.

4. All warranties, conditions and other terms implied by statute or common law (save for the conditions implied by section 12 of the Sale of Goods Act 1979) are to the fullest extent permitted by law excluded from the agreement.


5. Except in the event of fraud or negligent misrepresentation, the Company shall not be liable to the Customer for any delay in performing, or any failure to perform, any of the Company's obligations in relation to the services, if the delay or failure was due to any cause beyond the Company's reasonable control.



GROUND FLOOR PLAN




FIRST FLOOR PLAN



SECTION B-B

SECTION A-A

all new windows and external doors to be double glazed and to have a 'U' value of 1.2 W/m² K glazing to doors to be in safety glass provide background ventilation of 3000 mm² to new and extended habitable rooms install extractor fan to kitchen as schedule install extractor fan to utility room and to w.c. compartment. Fans wired to light switches and to provide 3 air changes per hour with 15 minute overrun, duct through to external as minimum extract fan to utility room 30 litres/second sanitary fittings connected to relevant sup or stud stack in single stack. stud partition walls 100 x 50 mm studwork lined both sides with 12.5 mm plasterboard, 100 mm Rockwool mineral quilt between studding



LOCATION PLAN Scale 1:1250

0 20 40 60 80 100 metres
Scale Bar 1:1250

0 1 2 3 4 5 metres
Scale Bar 1:50 and 1:100

REVISION

8165 PCS
SCALE 1:50 & 1:100
PROJECT INTERNAL ALTERATIONS, CONVERSION OF GARAGE INTO HABITABLE ROOM AND ENCLOSURE OF FRONT CANOPY ROOM
LOCATION 21 MALVERN AVENUE, BEXLEYHEATH DA7 5LE

CLIENT DATE May 2021

Colin Luther Associates Ltd
25 B Pickford Road
Bexleyheath
Kent DA7 4AG
Email: cwplans@aol.com
Tel: 020 8 820 2100

Architectural Consultants
Colin Luther