

Wall ties with insulation retaining clip as structural engineers specification. Wall ties to be within 225mm of opening and not more than 300mm vertical spacing 102.5mm brickwork with 70mm clear cavity (53mm at recessed brick feature detail) with 75mm rigid insulation board, Celotex CW4000 or equal approved with thermal conductivity of 0.022 W/mk, and 100mm medium density concrete blockwork (7.3N), with 12.5mm plasterboard on adhesive dabs and 2.5mm thick plaster skim coat, to acheive a minimum U-value of 0.21W/m²K Section Through Recessed Brickwork

1:5

1 Typical Arched Window Head Detail

A 06/09/21 KLM Minor amendments to suit client comments. PROJECT Panflora Nurseries

BOWKER SADLER PARTNERSHIP LIMITED

BE IDENTIFIED AS THE AUTHOR OF THIS DESIGN

■ REPORT ERRORS & OMISSIONS TO ARCHITECT.

DRAWING NOT TO BE SCALED.

■ CHECK ALL DIMENSIONS ON SITE

■ THIS DRAWING IS THE SUBJECT OF COPYRIGHT WHICH VESTS IN BOWKER SADLER PARTNERSHIP LIMITED. IT IS AN INFRINGEMENT OF COPYRIGHT TO REPRODUCE THIS DRAWING, BY WHATEVER MEANS, INCLUDING ELECTRONIC, WITHOUT THE EXPRESS WRITTEN CONSENT OF BOWKER SADLER PARTNERSHIP LIMITED WHICH RESERVES ALL ITS RIGHTS

BOWKER SADLER PARTNERSHIP LIMITED ASSERTS ITS RIGHTS TO

■ DRAWING TO BE READ IN CONJUNCTION WITH THE HEALTH AND

SAFETY PLAN AND ALL RELEVANT RISK ASSESSMENTS

Edgefold Homes Ltd.

Typical Section Details
Sheet 5

CHECKED DATE ADS @ A1 KLM 06/08/2021

BOWKER SADLER ARCHITECTURE

- A: Hatherlow House, Hatherlow, Romiley, Stockport SK6 3DY
- T: 0161 406 7333
- E: office@bowker-sadler.co.uk W: www.bowker-sadler.co.uk

DRAWING No **6504** ^{JOB №} 18062 REVISION

Building Regulations