

Warning External

From: John Mills
Sent: Tue, 4 Jan 2022 13:34:32 +0000
To: Dev Control Enquiries
Cc: John Mills
Subject: Our ref: 21/13098/PLACON Your ref: Ref: 21/00761/FUL

I can confirm that I have no objection to the proposals in principle.

The proposed development is within influencing distance of an area that was extensively mined. It appears that the proposed development will also require the removal or disturbance of areas of hardstanding which may expose contaminated fill material. I therefore recommend the following conditions:

1. Before the commencement of the development hereby approved:

- a. A Phase I contaminated land assessment (desk-study) shall be undertaken and approved in writing by the local planning authority.
- b. The contaminated land assessment shall include a desk-study with details of the history of the site use including:
 - the likely presence of potentially hazardous materials and substances,
 - their likely nature, extent and scale,
 - whether or not they originated from the site,
 - a conceptual model of pollutant-receptor linkages,
 - an assessment of the potential risks to human health, property (existing or proposed) including buildings, crops, livestock, pets, woodland and service lines and pipes, adjoining land, ground waters and surface waters, ecological systems, archaeological sites and ancient monuments,
 - details of a site investigation strategy (if potential contamination is identified) to effectively characterise the site based on the relevant information discovered by the desk study and justification for the use or not of appropriate guidance. The site investigation strategy shall, where necessary, include relevant soil, ground gas, surface and groundwater sampling/monitoring as identified by the desk-study strategy

The site investigation shall be carried out by a competent person in accordance with the current U.K. requirements for sampling and analysis. A report of the site investigation shall be submitted to the local planning authority for approval.

2. Before the commencement of the development hereby approved:

Where the site investigation identifies unacceptable levels of contamination, a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property and the natural and historical environment shall be submitted to and approved in writing by the local planning authority. The submitted scheme shall have regard to relevant current guidance. The approved scheme shall include all works to be undertaken, proposed remediation objectives and remediation criteria and site management procedures. The scheme shall ensure that the

site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 in relation to the intended use of the land after remediation.

The developer shall give at least 14 days notice to the Local Planning Authority (Environmental Health Division) prior to commencing works in connection with the remediation scheme.

3 No [dwellings/buildings] hereby approved shall be occupied until:

- a. The approved remediation works required by 2 above have been carried out in full in compliance with the approved methodology and best practice.
- b. If during the construction and/or demolition works associated with the development hereby approved any suspected areas of contamination are discovered, which have not previously been identified, then all works shall be suspended until the nature and extent of the contamination is assessed and a report submitted and approved in writing by the local planning authority and the local planning authority shall be notified as soon as is reasonably practicable of the discovery of any suspected areas of contamination. The suspect material shall be re-evaluated through the process described in 1b to 2 above and satisfy 3a above.
- c. Upon completion of the remediation works required by 2 and 3a above a validation report prepared by a competent person shall be submitted to and approved in writing by the local planning authority. The validation report shall include details of the remediation works and Quality Assurance/Quality Control results to show that the works have been carried out in full and in accordance with the approved methodology. Details of any validation sampling and analysis to show the site has achieved the approved remediation standard, together with the necessary waste management documentation shall be included.

REASON: To protect future occupiers of the development, buildings, structures/services, ecosystems and controlled waters, including deep and shallow ground water.

Kind regards,

John Mills
Principal Environmental Health Officer
Environmental Protection
T: 01283 595903
M: 07976 081884
www.southderbyshire.gov.uk



Our Environment | Our People | Our Future

www.southderbyshire.gov.uk



To view South Derbyshire District Council Privacy Notices please visit
<https://www.southderbyshire.gov.uk/privacy>

The views expressed in this email are personal and may not necessarily reflect those of South Derbyshire District Council, unless explicitly stated otherwise. This email, and any files transmitted with it, are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify me immediately. If you are not the intended recipient of this email, you should not copy it for any purpose, or disclose its contents to any other person. Senders and recipients of email should be aware that under the Data Protection Act 2018 and Freedom of Information Act 2000, the contents may have to be disclosed. This message and attached files have been virus scanned. Attachments are opened at your own risk, we recommend that you check all emails with an appropriate virus scanner.