

Your Ref:DC/20/03434
Our Ref: SCC/CON/3321/20
Date: 3 September 2020
Highways Enquiries to: Highways.DevelopmentControl@suffolk.gov.uk



All planning enquiries should be sent to the Local Planning Authority.

Email: planning@babberghmidsuffolk.gov.uk

The Planning Department
Babergh District Council
1st Floor
Endeavour House
8 Russell Road
Ipswich
Suffolk
IP1 1BX

For the attention of: Lynda Bacon

Dear Lynda,

TOWN AND COUNTRY PLANNING ACT 1990

CONSULTATION RETURN: DC/20/03434

PROPOSAL: Full Planning Application - Conversion of (part converted) single storey barns to form 2no holiday lets.

LOCATION: Trucketts Hall Glemsford Road Boxted Suffolk IP29 4LJ

ROAD CLASS:

Notice is hereby given that the County Council as Highway Authority recommends that any permission which that Planning Authority may give should include the conditions shown below:

Condition: Prior to the dwellings hereby permitted being first occupied, the existing access onto the highway shall be properly surfaced with a bound material for a minimum distance of 5 metres from the edge of the metalled carriageway, in accordance with details previously submitted to and approved in writing by the local planning authority.

Reason: To secure appropriate improvements to the vehicular access in the interests of highway safety.

Condition: Before the development is commenced details shall be submitted to and approved in writing by the Local Planning Authority showing the means to prevent the discharge of surface water from the development onto the highway. The approved scheme shall be carried out in its entirety before the access is first used and shall be retained thereafter in its approved form.

Reason: To prevent hazards caused by flowing water or ice on the highway.

Condition: Before the development is commenced details of the areas to be provided for the [LOADING, UNLOADING,] manoeuvring and parking of vehicles including secure cycle storage shall be submitted to and approved in writing by the Local Planning Authority. The approved scheme shall be carried out in its entirety before the development is brought into use and shall be retained thereafter and used for no other purpose.

Reason: To ensure the provision and long term maintenance of adequate on-site space for the parking and manoeuvring of vehicles in accordance with Suffolk Guidance for Parking (2019) where on-street parking and manoeuvring would be detrimental to highway safety.

Condition: Before the access is first used clear visibility at a height of 0.6 metres above the carriageway level shall be provided and thereafter permanently maintained in that area between the nearside edge of the metalled carriageway and a line 2.4 metres from the nearside edge of the metalled carriageway at the centre line of the access point (X dimension) and a distance of 90 metres in each direction along the edge of the metalled carriageway from the centre of the access (Y dimension).

Notwithstanding the provisions of Part 2 Class A of the Town & Country Planning (General Permitted Development) Order 1995 (or any Order revoking and re-enacting that Order with or without modification) no obstruction over 0.6 metres high shall be erected, constructed, planted or permitted to grow within the areas of the visibility splays.

Reason: To ensure vehicles exiting the drive would have sufficient visibility to enter the public highway safely, and vehicles on the public highway would have sufficient warning of a vehicle emerging to take avoiding action.

Comment:

We note the crash map data provided however due to the change of use on the access representing an intensification of use and people using the facility being unfamiliar with the area visibility splays are required.

It is an OFFENCE to carry out works within the public highway, which includes a Public Right of Way, without the permission of the Highway Authority.

Any conditions which involve work within the limits of the public highway do not give the applicant permission to carry them out. Unless otherwise agreed in writing all works within the public highway shall be carried out by the County Council or its agents at the applicant's expense.

The County Council's Central Area Manager must be contacted on Telephone: 0345 6066171. Further information go to: <https://www.suffolk.gov.uk/roads-and-transport/parking/apply-for-a-dropped-kerb/>

A fee is payable to the Highway Authority for the assessment and inspection of both new vehicular crossing access works and improvements deemed necessary to existing vehicular crossings due to proposed development.

Yours sincerely,

Mr Steve O'Kane
Development Management Technician
Growth, Highways and Infrastructure