



your energy assessor

**Fenton Energy Ltd.**

Ground Floor  
Parker Court  
Knapp Lane  
Cheltenham  
GL50 3QJ

01242 506150

info@fentonenergy.co.uk

www.fentonenergy.co.uk



**PROJECT NAME**

53 Springfield Road

**DATE**

29<sup>th</sup> June 2022

**ASSESSOR**

Benjamin Leech

# ENERGY STRATEGY

Compliance with BCS14

# Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

## Contents

Executive Summary.....	3
Total CO <sub>2</sub> Savings on Residual Emissions.....	3
Result.....	3
Disclaimer.....	3
Design Principles to Reduce Energy Consumption and Carbon Emissions.....	4
Fabric.....	4
Fenestration and Solar Gain.....	4
Mechanical Services.....	4
Lighting.....	5
Renewables.....	5
Overall performance.....	5
Proposed Fabric and Services Specification.....	6
Table 1 – Baseline Compliance.....	6
Table 2 – Additional Energy Efficiency Measures.....	7
Selecting Renewables.....	8
Table 3 – Feasibility Matrix of Appropriate Renewables.....	8
Fig. 1 – Aerial Image of the Site – Overshading Risk.....	9
Heat Hierarchy.....	9
Table 4 – Following the Heat Hierarchy.....	9
Fig. 2 – Bristol City Council Heat Networks Map.....	10
Feasibility of Appropriate Renewables – Conclusion.....	11
Appropriate Solution(s).....	11
Table 5 – Proposed Renewables.....	12
Table 6 – Summary Table.....	13
Appendix A – Plot Detail.....	14
Appendix B – Possible Solar Panel.....	15
Appendix C – Photovoltaic Panels.....	17
What are Photovoltaic Panels?.....	17
Space Requirements.....	17
Installation Costs, Funding, Maintenance and Payback.....	18
Advantages of Photovoltaic Panels.....	18
Disadvantages of Photovoltaic Panels.....	18
Appendix D – Solar Thermal Panels.....	19
What is Solar Thermal Energy?.....	19
Space Requirements.....	19
Installation Costs, Funding, Maintenance and Payback.....	20
Planning Requirements.....	20

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

Advantages.....	20
Disadvantages.....	20
Appendix E – Air Source Heat Pumps .....	21
What are Air Source Heat Pumps?.....	21
Space Requirements .....	22
Installation Costs, Funding, Maintenance and Payback .....	22
Planning .....	22
Advantages.....	22
Disadvantages.....	22
Appendix F – Ground Source Heat Pumps.....	23
What are Ground Source Heat Pumps?.....	23
Space Requirements .....	23
Installation Costs, Funding, Maintenance and Payback .....	24
Planning Requirements.....	24
Advantages.....	24
Disadvantages.....	24
Appendix G – Biomass.....	25
What is Biomass? .....	25
Space Requirements .....	25
Installation Costs, Funding, Maintenance and Payback .....	26
Planning .....	26
Advantages.....	26
Disadvantages.....	26
Appendix H – Combined Heat and Power .....	27
What is Combine Heat and Power? .....	27
Space Requirements .....	27
Installation Costs, Funding, Maintenance and Payback .....	28
Advantages.....	28
Disadvantages.....	28
Appendix I – District Heating .....	29
What is District Heating? .....	29
Space Requirements .....	29
Installation Costs, Funding, Maintenance and Payback .....	30
Advantages.....	30
Disadvantages.....	30



## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Executive Summary

This Energy Assessment has been compiled to demonstrate compliance with the Bristol City Council Policy BCS14 (from the Development Framework Core Strategy).

The proposal is for the erection of a pair of semi-detached houses on land to the rear of 53 Springfield Road, Cotham, Bristol, BS6 5SW.

Following the methodology outlined in the Climate Change and Sustainability – Practice Note, SAP calculations have been completed in stages to demonstrate a 20% reduction in regulated carbon emissions. As Part L 2021 came into force 15<sup>th</sup> June 2022, the SAP10 methodology has been used to calculate the expected carbon emissions and energy demand associated with the site.

Firstly, SAP calculations achieving Part L compliance were modelled to provide 'baseline' energy demand and emissions. Then, additional measures were applied to provide 'residual' energy demand and emissions. Finally, appropriate decentralised renewables were included in the SAP calculations to provide the final energy demand and emissions figures for comparison. More detail is provided in the following sections.

To summarize the results, the total reduction in carbon emissions from on-site renewables is as follows:

#### Total CO<sub>2</sub> Savings on Residual Emissions

**97.55%**

Result

**Pass**

### Disclaimer

The full SAP 10 software is not yet functional. As such, the SAP 10 beta software has been used to calculate the energy demand and emissions – although this may not exactly match the results from the full software (once this is useable) it will be indicative of the expected carbon reduction for the site.



## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Design Principles to Reduce Energy Consumption and Carbon Emissions

#### Fabric

Low U-values and good detailing will help to limit heat losses through the fabric of the proposed dwellings.

All non-repeating thermal bridges (such as those between the external walls and the roofs) will be specified to either Constructive Details, or Local Authority Building Control (LABC) Registered details, depending on which provides the best performance. This will ensure that heat losses through these junctions are minimised and that the corresponding psi values can be utilised in the SAP calculations.

#### Fenestration and Solar Gain

Careful consideration will be given to the fenestration, given that a considerable proportion of the façade will be glazed. Low U-values will need to be specified to limit heat losses through these areas. The glazing design allows for passive heating of the houses from solar gains. However, to minimise the risk of overheating within the dwellings, the glazing will be openable where practical and a combination of internal and external shading will be employed.

The positioning of the glazed openings will also maximise the available daylight into the building. This will not only improve comfort levels for the occupants but also reduce the energy consumption through artificial lighting.

#### Mechanical Services

A well-designed building envelope must be supplemented by appropriate services within the building.

It is proposed that the heating and hot water to the houses be provided by air source heat pumps.

Additionally, mechanical extract fans will be fitted to wet rooms.



## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Lighting

It is proposed that only energy efficient lighting is installed at the property. This means that all light fittings should have lamps with a luminous efficacy of greater than 100 lamp lumens per circuit-watt and a total output greater than 400 lamp lumens.

### Renewables

In addition to the use of a heat pump on site, other forms of renewable technologies have been considered. A photovoltaic panel array is required to achieve baseline compliance, in line with the new regulations, and has been retained through the remaining assessment stages.

### Overall performance

The following tables detail how the proposed building has been specified at this stage, incorporating the above principles. Also displayed is how the building performs in relation to the building regulations and the planning requirements for BCS14.

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

### Proposed Fabric and Services Specification

Table 1 – Baseline Compliance

Showing the minimum specification required to achieve compliance with Part L. The specification is assumed at this stage as no specific build-ups are currently available.

Category	Item	Value/Details	Part L Minimum Standard
<b>Building Fabric (W/m<sup>2</sup>K)</b>	Ground Floor	0.13	0.18
	Exposed Floor Above Bin Store	0.13	0.18
	External Walls	0.18	0.26
	Loft and Dormer Walls	0.18	0.26
	Pitched Roof, Sloping Ceiling	0.11	0.16
	Pitched Roof, Flat Ceiling	0.09	0.16
	Flat Roof	0.11	0.16
<b>Fenestration (W/m<sup>2</sup>K)</b>	Solid Door	1.00	1.40
	Fully Glazed Door	1.40	1.60
	Window	1.40	1.60
<b>Thermal Bridging (γ-value)</b>	LABC Registered Details and Constructive Details	0.0768	As calculated for individual units
<b>Ventilation</b>	Air Permeability (m <sup>3</sup> /hm <sup>2</sup> )	4.00	8.00
	Mechanical Ventilation	Natural Ventilation (Extract fans fitted to wet rooms)	Natural Ventilation
<b>Heating</b>	Primary Heating System	Ideal Logic Combi ESP1 30 (89.6% efficient) incorporating Flue Gas Heat Recovery	Gas combi boiler, minimum 88% efficient
	Controls	Time and temperature zone controls with a delayed start thermostat	Time and temperature zone controls
	Heat Distribution	Radiators	Radiators
	Water Heating	Combi	Combi
	Secondary Heating System	None	None
<b>Additional Features</b>	Low Energy Lighting	75lm/W	75lm/W
	SAP Appendix Q	None	None
	Renewables	2.25kWp PV, south-west facing	None (2.33kWp used in TER calculations)
	Regulation 36 Compliance	125 litres/person/day	125 litres/person/day

## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

Table 2 – Additional Energy Efficiency Measures

Showing updates to the baseline specification to reduce energy demand.

Category	Item	Value/Details	Part L Minimum Standard
<b>Heating</b>	Controls	Design flow temperature decreased to 35°C	Minimum design flow rate temperature 55°C
<b>Additional Features</b>	Low Energy Lighting	100lm/W	75lm/W



## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

### Selecting Renewables

Table 3 – Feasibility Matrix of Appropriate Renewables

Showing the considerations in choosing a renewable technology for this site.

Technology	Requirements	Requirements Met?	Appropriate?
Photovoltaic panels	Roof facing east to west (through south)	Yes	Yes
	Little/no or modest overshadowing	Yes*	
	Flat roof or pitched roof not greater than 45°	Yes	
	Any size development	Yes	
Solar thermal	All requirements as for photovoltaic panels	Yes	Yes
	Hot water tank possible	Yes	
Air source heat pumps	Suitable external wall or other location on-site for equipment	Yes	Yes
	Aesthetic considerations	Yes	
	Noise impact	Yes	
	Any size development	Yes	
Ground source heat pumps	External space for horizontal trench or vertical borehole	No	No
	Medium to large sized development	No	
	Archaeology	Unknown	
	Best suited to underfloor heating	No	
Biomass	Space needed for plant, fuel storage and deliveries	No	No
	Medium to large sized development	No	
	Minimal impact on residents (air quality, deliveries)	No	
Combined heat and power	Space need for plant, access and servicing	No	No
	Large sized development (large heat demand)	No	
District heating	Available network	No	No
	Very large sized development (substantial heat demand)	No	

\*See the following aerial image demonstrating that the overshadowing risk is low for the likely location of any solar panels.

Please refer to Appendices C through I for more in-depth information on these technologies.

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

Fig. 1 – Aerial Image of the Site – Overshading Risk



*Note: the blue arrow shows the location of the proposed new dwellings. As can be seen, once the three trees on site have been removed to make way for the new dwellings, there will be no obstructions likely to overshadow potential solar panels.*

### Heat Hierarchy

Table 4 – Following the Heat Hierarchy


Showing how the heat hierarchy, as outlined in BCS14 can be applied to this site.

Stage	Feasible	Notes
1. Connection to existing CHP/CCHP distribution networks	No	No network available
2. Site-wide renewable CHP/CCHP	No	Only a single unit proposed for the site
3. Site-wide gas-fired CHP/CCHP	No	Only a single unit proposed for the site
4. Site-wide renewable community heating/cooling	No	Only a single unit proposed for the site
5. Site-wide gas-fired community heating/cooling	No	Only a single unit proposed for the site
6. Individual building renewable heating	Yes	Air source heat pump is feasible

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

Fig. 2 – Bristol City Council Heat Networks Map



*Note: the blue arrow shows the approximate location of 53 Springfield Road. As can be seen, the site does not lie within the scope of any existing or proposed heat network.*



## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Feasibility of Appropriate Renewables – Conclusion

Due to the location, size and type of development most renewable technologies are not appropriate for this site.

In the future, if a district heating system were to be introduced to the area, the proposed dwellings could be connected to this network. This could be facilitated as wet central heating systems are planned for this development.

Photovoltaic panels are feasible for this development. However, as a 2.25kWp PV array is required to achieve baseline compliance under the new regulations, which represents the largest array that could fit onto the available roof space, there is no scope for a PV array to be used to achieve a carbon reduction beyond baseline compliance.

However, an air source heat pump, in combination with a hot water cylinder, is capable of providing a carbon reduction far in excess of the required 20% reduction, as demonstrated in Table 6 below. This assumed a suitable location for the external equipment can be found, which will need to be confirmed by survey prior to installation.

### Appropriate Solution(s)

<b>ASHP</b>
-------------

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

Table 5 – Proposed Renewables

Showing renewables added to the specification to reduce carbon emissions.

Category	Item	Value/Details	Part L Minimum Standard
Heating	Primary Heating System	Air Source Heat Pump, e.g. Mitsubishi Ecodan PUZ-WM60VAA	-
	Water Heating	210l cylinder fed from heat pump, e.g. Mitsubishi EHPT21X-UKHCW (declared heat loss 1.57kWh/day)	-

**Please note the following:**

The stated carbon reduction requires that the PV array required for baseline compliance be installed in addition to the heat pump, although full building regulations compliance can be achieved without the PV array if the heat pump is installed.

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

Table 6 – Summary Table

Showing how energy demand and carbon emissions can be reduced by implementing the measures detailed in the preceding steps.

	Energy demand (kWh pa)	Energy saving achieved (%)	Regulated CO <sub>2</sub> emissions (kg pa)	Saving achieved on residual CO <sub>2</sub> emissions (%)
Building Regulations Part L compliance (“Baseline” energy demand and emissions)	7,539.40		1,823.70	
Proposed scheme after energy efficiency measures and CHP (“Residual” energy demand and emissions)	7,135.40	5.36	1,739.12	
Proposed scheme after on-site renewables	313.62	95.60	42.66	97.55
Proposed scheme offset for financial contribution or other “allowable solution”			N/A	N/A
Total savings on residual emissions				97.55

For further details please refer to the SAP Reports and the appendices.



## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix A – Plot Detail

Plot	Baseline Energy Demand (kWh pa)	Baseline CO <sub>2</sub> (kg pa)	Additional Measures Energy Demand (kWh pa)	Additional Measures CO <sub>2</sub> (kg pa)	Renewables Demand (kWh pa)	Renewables CO <sub>2</sub> (kg pa)
Plot 1	3,769.70	911.85	3,567.70	869.56	156.81	21.33
Plot 2	3,769.70	911.85	3,567.70	869.56	156.81	21.33

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)


### Appendix B – Possible Solar Panel



**VITOVOLT 300**

Photovoltaic modules  
Type M395WE, M400WE  
standard and blackframe

Datasheet



**VITOVOLT 300** Type M395WE, M400WE

Monocrystalline photovoltaic modules in **standard** and **blackframe** versions with 395/400 W<sub>p</sub> rated output for generating power from solar energy

- Module efficiency up to 20.4 %
- Shingled PERC cell technology
- Corrosion-resistant aluminium frame with excellent mechanical load bearing capacity for high snow (5400 Pa) and wind/suction (2400 Pa) loads
- Additional output of up to 5 W<sub>p</sub> due to positive output tolerance
- 3.2 mm anti-reflective glass for high solar yields
- High operational reliability: 2 bypass diode bridges for dependable operation
- Tested for resistance to salt spray and ammonia. Consequently suitable for use in coastal regions and areas with intensive agricultural operations
- Certified to IEC 61215, IEC 61730, IEC 61701 and IEC 62716 to guarantee compliance with international quality standards.

6169122 GB 11/2020




## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

### Specification

Vitovolt 300	Type	M395WE	M400WE	Vitovolt 300	Type	M395WE	M400WE
<b>Performance data under STC</b>				<b>Cell temperature at NOCT</b>			
Rated output $P_{max}$	$W_p$	395	400	°C		42.3	42.3
Output tolerance	W	0/+5	0/+5	<b>Max. system voltage</b>	V	1500	1500
MPP voltage $U_{mpp}$	V	38.5	38.6	<b>Reverse current resistance</b>	A	20	20
MPP current $I_{mpp}$	A	10.26	10.36	<ul style="list-style-type: none"> <li>■ STC: Insolation 1000 W/m<sup>2</sup>, cell temperature 25 °C, air mass AM 1.5, measuring tolerance: ±3 % (<math>P_{max}</math>)</li> <li>■ MPP = maximum power point (maximum output under STC)</li> <li>■ NOCT: Insolation 800 W/m<sup>2</sup>, ambient temperature 20 °C, air mass AM 1.5, wind speed 1 m/s, measuring tolerance: ±5 % (<math>P_{max}</math>)</li> </ul>			
Open circuit voltage $U_{oc}$	V	46.3	46.4				
Short circuit current $I_{sc}$	A	10.92	10.97				
Module efficiency	%	20.15	20.4				
<b>Temperature coefficients</b>							
Output	%/K	-0.34	-0.34				
Open circuit voltage	%/K	-0.27	-0.27				
Short circuit current	%/K	0.04	0.04				

### Connection dimensions



- (A) Junction box
- (B) Connecting cables
- (C) 4 drilled holes 9 x 14 mm
- (D) 4 holes for equipotential bonding,  $\varnothing$  6 mm

a	mm	1719
b	mm	1140
c	mm	1090
d	mm	1031
f	mm	35
g	mm	35

Type of cell	Monocrystalline PERC silicon cell
Number of cells	340 (shingled)
Cell embedding	Ethylene vinyl acetate (EVA)
Frame	Anodised aluminium alloy, black/silver
Front glass	Thermally toughened safety glass 3.2 mm with anti-reflective coating
Weight	22 kg
Max. load due to pressure/suction	5400 Pa/2400 Pa
Junction box	IP 67, 3 diodes
Connection	Cables 1.25 m long, with 4 mm <sup>2</sup> cross-section and Multi-Contact (MC4)
Protection class	II
Application class	A
Shipping unit	31 pce per pallet

### Guarantee

#### Product guarantee

5 years: Viessmann warranty  
12 years: Viessmann product guarantee

#### Output guarantee

Min. 97 % after one year  
Min. 80 % linear after 25 years

#### Note

Product and output guarantee in accordance with the guarantee conditions of Viessmann Werke GmbH & Co. KG. Guarantee conditions: [www.viessmann.de/Llogin](http://www.viessmann.de/Llogin).

#### Tested quality

Certified to IEC 61215, IEC 61730, IEC 61701 and IEC 62716. Manufactured in factories certified to ISO 9001 and 14001. CE designation according to current EC directives.

Subject to technical modifications.

Viessmann Werke GmbH & Co. KG  
D-35107 Allendorf  
Telephone: +49 6452 70-0  
Fax: +49 6452 70-2780  
[www.viessmann.com](http://www.viessmann.com)

Viessmann Limited  
Hortonwood 30, Telford  
Shropshire, TF1 7YP, GB  
Telephone: +44 1952 675000  
Fax: +44 1952 675040  
E-mail: [info-uk@viessmann.com](mailto:info-uk@viessmann.com)

2 **VIESSMANN**

**VITOVOLT 300**

6169122

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix C – Photovoltaic Panels

#### What are Photovoltaic Panels?

Photovoltaic Panels (PV) panels convert the energy in light received from the Sun into electricity. There are two types of system – grid connected systems are the most common and allow electricity to be drawn from the national grid during times when the panels are not generating enough electricity to provide all the power needs. This setup also allows any surplus electricity to be sold back to the grid. Conversely, standalone systems are not connected to the grid and so require supplementing with other power generating systems or batteries to ensure that the supply of electricity is not interrupted.



#### Space Requirements

PV Panels are composed of a series of small solar cells that are connected together. They come in a variety of shapes, sizes and outputs and ideally will be installed on an inclined south-facing roof to maximise the power generated. Larger arrays will result in more power being generated, up to the limits of available roof space. If space is limited, solar tiles can be installed as these can fit more capacity into the same area. However, these are more expensive than traditional panel installations.



## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

The average cost for a solar panel installation for a small-scale building is approximately £5,000-£9,000, although this is highly dependent on the size of array being installed. Planning permission is not usually required unless the panels are to be installed on a listed building or the property is situated in a conservation area.

The photovoltaic array can be expected to last for up to 25 years, depending on the manufacturer.

On January 1<sup>st</sup> 2020, a new government incentive scheme was introduced, known as the Smart Export Guarantee (SEG). For those installing small scale renewable technologies, with a maximum capacity of 5MW, the SEG will pay for each unit of electricity fed into the National Grid. It is anticipated that payback for a PV system could be achieved in approximately 12 years.

### Advantages of Photovoltaic Panels

- Electricity bills reduced
- Source of renewable energy
- Reduced carbon footprint
- Low maintenance

### Disadvantages of Photovoltaic Panels

- Relatively high upfront cost
- Energy generation varies with the average annual amount of radiation received
- Power output highly weather dependent
- No electricity produced at night
- Requires a lot of roof space for an effective array.

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix D – Solar Thermal Panels

#### What is Solar Thermal Energy?

A solar thermal system uses energy from the Sun to heat water which is then stored in a hot water cylinder.



#### Space Requirements

For a small scale solar thermal setup, it is suggested that approximately five square meters of south facing space will be required, to ensure that as much solar energy as possible can be collected. A sloping roof is not required as the panels can be fitted to a frame mounted on a flat roof or even hung from a wall.

Before installing a solar thermal system, it is important to check if your current setup is suitable – solar thermal systems require a hot water cylinder to store the heated water and are therefore not compatible with combination boilers or direct acting water heaters. If the cylinder present prior to the installation of the solar thermal system is not a solar cylinder, it will be necessary to either replace the cylinder with one which has a solar heating coil fitted or to add an extra cylinder with a solar coil to ensure that the system works correctly.

## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

The initial cost of installing a typical small scale solar thermal system is generally between £5,000 and £9,000. There are currently no financial schemes available for solar thermal panels.

Very little maintenance is usually required after the system is installed, although it is important to have the system inspected every three to seven years by a qualified solar panel expert.

The payback costs for solar panels depend greatly on the installation costs. For example, a system costing between £5,000 and £7,000 to install has a typical payback time between 13 and 17 years.

### Planning Requirements

Planning permission is generally not required for the installation of a solar thermal system. However, restrictions may apply if the building is listed or sited within a conservation area – it is advisable to check with the local council prior to installation.

### Advantages

- Clean and efficient water heating
- Easy to maintain
- Quiet
- Low carbon footprint

### Disadvantages

- High initial cost
- Effectiveness depends on the number of hours of sunshine your area gets during the day
- The system is limited to only heating water – no electricity is produced
- Only useful if there is meaningful hot water demand

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix E – Air Source Heat Pumps

#### What are Air Source Heat Pumps?

Air source heat pumps (ASHPs) extract thermal energy from outside air (using the principles of vapour compression refrigeration), which can then be used to heat the building as well as to provide hot water. Heat pumps can also be run in reverse, cooling the building and transferring the excess heat to the outside.

There are two types of air source heat pump systems:

1. **Air to air** systems transfer the warmed air throughout the building using fans
2. **Air to water** systems transfer heat to water, which is then distributed via plumbing similar to that used in a conventional heating system with a boiler

Air source heat pumps operate at lower temperatures than traditional gas boilers. This means that these systems can be utilised more effectively with an underfloor heating setup compared to using radiators, as with underfloor heating the warmth is distributed more evenly and thus more efficiently. It is vital that the building fabric be well insulated if the benefits of an air source heat pump are to be fully utilised.





## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Space Requirements

An area on the exterior of the building, such as on a wall or roof, will be required for the external unit. This ideally should be in a warmer location which not only has enough space for the unit but is also clear of obstructions to allow air to flow freely.

Additionally, space will be required for the internal unit. Typically, these are no larger than a standard hot water cylinder or boiler unit, depending on the exact setup used. However, with many setups a separate hot water cylinder, along with the space for this, is also required.

### Installation Costs, Funding, Maintenance and Payback

The cost of purchasing and installing an air source heat pump system is generally between £3,000 and £11,000, depending on the size and complexity of the setup. Additional costs may be incurred if your property is particularly large. However, it may be possible to obtain payments from the Government's Renewable Heat Incentive (RHI), which will offset some of the costs incurred with installing the heat pump.

Air source heat pumps can be expected to last for up to 20 years as long as they are inspected every three to five years by a qualified technician. A typical payback period for ASHPs is around 12 years, once RHI is taken into account.

### Planning

It is advisable to consult your local planning authority prior to purchasing the heat pump to establish whether there are any restrictions as to the positioning of the external unit.

### Advantages

- Lower fuel bills
- Can provide heating in winter and cooling in the summer as well as hot water year-round
- Low maintenance
- Low carbon footprint

### Disadvantages

- Works more efficiently with underfloor heating, or larger radiators
- The outdoor unit produces noise so careful siting is required
- Less efficient in winter due to the need to extract heat from colder air, resulting in lower Coefficient of Performance (COP) values.

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix F – Ground Source Heat Pumps

#### What are Ground Source Heat Pumps?

Ground source heat pumps (GSHPs) use pipes, buried in available land close to the building, to extract heat from the ground. Water and antifreeze are circulated around the pipes absorbing heat, which is then transferred through a heat exchanger in the heat pump into the building. From this point, the heat can be used to provide space or hot water heating, or the system can be run in reverse to provide cooling.

Ground source heat pumps operate at lower temperatures than traditional gas boilers. This means that these systems can be utilised more efficiently with an underfloor heating setup than with radiators. It is particularly vital that the building be well insulated to fully take advantage of the benefits of a ground source heat pump.



#### Space Requirements

There are two types of ground source heat pump systems:

1. **Horizontal** systems, which require an area of approximately 700m<sup>2</sup>
2. **Vertical** systems, which have a borehole approximately a quarter of a metre across and up to 100m deep.

Larger sites will require either a larger area or more boreholes. Whichever system is chosen, suitable access must be available for the machinery required to install the pipework, especially in the case of the drill rig required for the vertical systems.

Space must also be available for the internal unit. These are typically larger than a standard gas boiler, approximately the size of a domestic hot water cylinder.





## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

Installing ground source heat pumps can cost between £10,000 and £18,000. The horizontal system is often cheaper as the expensive drill rig required to drill the borehole is unnecessary.

It may be possible to obtain payments from the Government's Renewable Heat Incentive (RHI), which will help to offset some of the costs involved with installing the heat pump. Additionally, the heat pump, if inspected regularly by a qualified servicer, can be expected to last for up to twenty years.

With low running costs and possible income from the RHI, the payback period can typically be between 8 and 12 years.

### Planning Requirements

Ground source heat pumps are generally permitted, but some restrictions apply, such as with listed buildings. Consulting your local authority prior to installation is recommended.

### Advantages

- Lower fuel bills, especially if used to replace direct electric heating
- Can provide both space and hot water heating
- Can provide heating in winter and cooling in summer as well as hot water year-round
- Lower carbon footprint
- Low maintenance
- More efficient in winter than air source heat pumps due to ground temperatures remaining more constant throughout the year

### Disadvantages

- More expensive to install than air source heat pumps
- Suitable land must be available for the pipework or boreholes
- The building must be very well insulated
- Works most efficiently with underfloor heating or warm air distribution

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix G – Biomass

#### What is Biomass?

Biomass is any fuel obtained from natural or organic material, such as manure, forest debris or agricultural or horticultural waste. The most common biomass energy source is wood in the form of pellets, wood chips or logs. Biomass boilers can be used as a replacement for a fossil fuel-based heat source, and are best suited to medium to large scale sites.



#### Space Requirements

Typically, biomass boilers are contained in a single plant room serving the whole site. This room needs to be big enough for the boiler or boilers themselves, along with water tanks and space for fuel storage.

## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

The cost of a biomass boiler depends on a number of factors, including the type of boiler used, the fuel type and storage size. For example, the cost, including installation, of an automatically-fed pellet boiler can be as much as £20,000. It is important to note that biomass boilers are also eligible for the Government Renewable Heat Incentive (RHI) scheme, which provides payments to those using renewable heating systems. Therefore, despite the high initial cost, biomass boilers can have relatively short payback times of around 5-7 years.

Biomass boilers should be serviced every 12 months to ensure continued efficiency and to prevent any breakdowns.

### Planning

There may be restrictions on the installation of biomass systems, due to concerns over local pollution and disruption to residents caused by deliveries.

### Advantages

- Sustainable energy source
- Reduces dependence on fossil fuels
- Carbon-neutral – the carbon produced is absorbed by plants which can then be used as future biomass fuel
- Reduces waste sent to landfill
- Abundant availability of fuel

### Disadvantages

- The burning of biomass fuels produces various gases that can contribute to local air pollution
- Space is required on-site for a plant room and fuel storage, as well as a designated fuel delivery area
- Constructing and operating biomass energy plants are often more expensive than more traditional power plants

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix H – Combined Heat and Power

#### What is Combined Heat and Power?

Combined Heat and Power (CHP), sometimes referred to as cogeneration, is a setup in which heat and power are generated simultaneously.

Energy which is lost at various steps in producing electricity in a conventional power plant can be captured and used to provide warmth. For example, water which has condensed from the steam used to turn the generating turbine is typically cooled in large cooling towers, with all the energy lost to the air. In a CHP plant, this 'waste' heat is instead used to produce hot water, hot air or steam, which can then be distributed to heat local buildings.



#### Space Requirements

Significant space is required for the power plant itself, as well as the additional space required for the recovery of the otherwise wasted heat. Additionally, to use this energy effectively, a large pipe network is needed to distribute the heat around the local area.

## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

The costs involved with setting up a CHP system, especially if the power plant is being constructed along with it rather than converted, are relatively high. As a result of this, these schemes tend to be large-scale long-term projects.

The network must be kept well maintained to avoid loss of service and to ensure continued operation. However, a large-scale network can heat a wide area more efficiently than with individual building heating systems, providing good long-term return on investments.

### Advantages

- The CHP process can be applied to power plants that use either renewable or fossil fuels as well as those which use a combination of the two
- Emissions are generally lower than other electricity and heat producing systems
- A variety of energy consumers can benefit from the installation of a CHP plant, including hospitals, schools and industrial sites

### Disadvantages

- CHP plants need to be local to their users to ensure as little energy is lost in the transmission as possible.
- The technology needed is expensive and more complex. Maintenance costs can also be greater
- Considerable amount of space is required for a full-size CHP setup, making it suitable only for larger sites

## Energy Strategy

Project: 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Appendix I – District Heating

#### What is District Heating?

Instead of relying on one boiler for each unit on site, district heating utilises hot water or steam from a single communal heat source and distributes that energy to a variety of consumers through a network of insulated pipes. This network can be as large as desired, allowing entire communities to benefit, as well as reducing the need for additional energy to be produced specifically for heating buildings in the local area.

In the individual property or building, a heat interface unit (HIU) gives the consumer control over the hot water they use in a similar manner to that provided by a traditional boiler.



#### Space Requirements

An energy centre or large plant room would be required for this type of system. Depending on the scale of the heat network, pipework may need to be laid underground to distribute the hot water across the site or to the local area.



## Energy Strategy

**Project:** 4404KJ – 2022.06 SS (53 Springfield Road – Florence Mae Ltd.)

---

### Installation Costs, Funding, Maintenance and Payback

The initial cost of setting up district heating, including the plant and infrastructure needed to deliver the heat, is relatively high and so these large-scale schemes tend to be a long-term investment.

Regular maintenance is essential to ensure continued efficiency and to prevent any breakdowns.

### Advantages

- More energy efficient as energy which is otherwise wasted can be used
- Lower carbon emissions
- Has the potential to reduce heating costs

### Disadvantages

- If the main fuel source experiences problems, whole areas could potentially be without heating or hot water
- Can in some cases be more expensive than traditional heating
- A large network is required to gain full benefit – it is only suitable for use on very large sites or where there is a network already present