
From: Sam Dowley <sam@dowleycoarc.com>

Sent: 27 September 2022 15:48

To: Connor Small [REDACTED]

Cc: Mortimer, Darre [REDACTED]

Steven King <[REDACTED]>

Subject: 22/01559/F The Maltings, Tower Road, Burnham Overy Staithe.

Good afternoon Connor, Darren and Steven,

I have prepared a formal re-submission based on the conversations I've had with both Darren and Steven. Please see the attached.

As I know you (Connor) are on holiday at the moment, I have cc'd Darren and Steven into this email.

Darren/ Steven could you please review the following and let me know your thoughts.

Darren: The parking will remain largely as existing however with a greater entry width to accommodate a modern vehicle. Currently the opening measures 2380mm across.

Steven: The high level windows on the North Facade have been re-sized and re-arranged. The two new windows on the West Facade have also been resized and aligned. There have also been some adjustments to the arrangement and quantity of conservation roof lights. As the parking will remain largely as is, the garden wall will also remain largely as is however with the opening increased to accommodate a larger vehicle.

We are looking to resolve these items of concern as soon as possible.

Please let me know if you have any further concerns.

Best regards,

Sam Dowley

Architect ARB, RIBA/ Arkitekt MAA



Dowley & Co. Ltd

dowleycoarc.com

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify sam@dowleycoarc.com. Information or opinions in this email which do not relate to the official business of Dowley & Co. Ltd are neither given nor endorsed. Dowley & Co. Ltd is a Limited Company incorporated in England and Wales.