













- NOTES**
1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION UNLESS MARKED ABOVE 'FOR CONSTRUCTION'
 2. THE COPYRIGHT ON THIS DRAWING IS RETAINED BY MICHAEL BEARDSALL ASSOCIATES LTD.
 3. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS
 4. THE CONTRACTOR IS RESPONSIBLE FOR ALL DIMENSIONS AND THE CORRECT SETTING OUT ON SITE. ONLY FIGURED DIMENSIONS ARE TO BE USED
 5. ALL MATERIALS AND WORKMANSHIP TO COMPLY WITH THE CURRENT BRITISH STANDARDS AND CODES OF PRACTICE



CBR OF SUBGRADE	MINIMUM CAPPING and SUB-BASE THICKNESS		
	CAPPING LAYER (mm)	SUB-BASE (mm)	OVERALL THICKNESS (mm)
UNSER 2%	DESIGN MUST BE APPROVED AND AGREED WITH THE ENGINEER BEFORE ANY WORKS COMMENCE		
2% - 3%	250	150	400
3% - 4%	200	150	350
4% - 8%	150	150	300
8% - 13%	0	225	225
ABOVE 13%	0	150	150

THE CAPPING LAYER SHALL CONSIST OF MATERIAL IN ACCORDANCE WITH CLAUSE 613 (CLASS 4F2) OR RECYCLED MATERIAL TO THE SATISFACTION OF THE PROJECT ENGINEER



TYPICAL REINSTATEMENT OF CARRIAGEWAY DETAIL (DEPTH DIMS ASSUMED)
SCALE 1:10

- NOTES**
1. EXISTING SURFACING TO BE CUT BACK TO A CLEAN EDGE AND TREATED IN ACCORDANCE WITH CLAUSE 704.
 2. CONSTRUCTION MATERIALS AND THICKNESSES SHALL BE IN ACCORDANCE WITH APPENDIX 7.1.
 3. JOINTS IN SURFACE COURSE ARE TO BE PERPENDICULAR TO, OR PARALLEL WITH, THE CARRIAGEWAY WIDTH.
 4. IF THE REMAINING DEPTH OF EXISTING BITUMINOUS MATERIAL BETWEEN G AND H IS LESS THAN 100 IT IS TO BE EXCAVATED AND REPLACED WITH FULL NEW CARRIAGEWAY CONSTRUCTION.

PI	06.08.21	ISSUED FOR PRELIMINARY	EO	SH
DATE		REVISION SUMMARY	BY	CHK
JOB TITLE: PROPOSED RESIDENTIAL DEVELOPMENT 21 DWELLINGS AT CRAPSTONE DEVON				
CLIENT: MR & MRS BOXALL				
DETAIL: CONSTRUCTION DETAILS				
DRN. BY: E.OREILLY				
DATE:	AUG 2021	SCALE:	AS SHOWN • A1	
JOB NO.:	21164	DRAWING No.:	310	REV.:
				P2
MBA CONSULTING				
Boscawen House · Chapel Hill · Truro · Cornwall TR1 3BN Tel. 01872 260962 Fax. 01872 260963				