


Phoned 9/1/2023  
he told me everything  
Okay with Sewage Systems as  
Per application by Liam.



**Cyfoeth  
Naturiol  
Cymru  
Natural  
Resources  
Wales**

Reg. Customer I.D No: CUS237357

Date: 10/05/2022

Dear Liam Kirwan,

**Environmental Permitting (England and Wales) Regulations 2010  
Confirmation of Registration – Water Discharge Exemption**

**Exemption Ref:** NRW-WQE073840

**Location of the Operation:** Glebe Cottage, Llantillio Pertholey, Nr Abergavenny, Abergavenny, Monmouthshire, NP7 6NU

Following receipt of your submission, we can confirm that we have now registered the operation(s) listed on the attached schedule, as exempt under the above Regulations, at the site shown.

If any of these exempt operations were previously authorised by a permit which you now consider to be redundant, please contact our Customer Care Centre on 0300 065 3000 so that we can explain what will happen to your permit.

The exemption(s) will remain valid at this site indefinitely.

If your operations change at anytime during the registration period please contact our Customer Care Centre on 0300 065 3000.

If you have any queries about this matter please contact us by telephone on 0300 065 3000 or email us at [enquiries@naturalresourceswales.gov.uk](mailto:enquiries@naturalresourceswales.gov.uk) quoting your site reference number NRW-WQE073840.

Yours sincerely

Helen Florek-Oughton  
Manager Customer Care Centre

Ffôn/Tel 0300 065 3000  
Ffacs/Fax 0844 892 0845  
Ebostr/Email [ymholiadau@cyfoethnaturiolcymru.gov.uk](mailto:ymholiadau@cyfoethnaturiolcymru.gov.uk)  
[enquiries@naturalresourceswales.gov.uk](mailto:enquiries@naturalresourceswales.gov.uk)

Canolfan Gwasanaethau Cwsmeriaid, Cyfoeth Naturiol Cymru, Ty Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP  
Customer Contact Centre, Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website [www.cyfoethnaturiolcymru.gov.uk](http://www.cyfoethnaturiolcymru.gov.uk)  
[www.naturalresourceswales.gov.uk](http://www.naturalresourceswales.gov.uk)

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg  
Correspondence welcomed in Welsh and English

## Schedule of exempt water operations

### Relevant objectives

In addition to the terms and conditions of the exemption, exempt activities must be carried out without endangering human health and without using processes or methods which could harm the environment and in particular without risk to water, air, soil, plants or animals; or causing nuisance through noise or odours; or adversely affecting the countryside or places of special interest.

### Details of exempt water operations

Name of Establishment or Undertaking:	
Trading name (if any):	<b>Not Applicable</b>
Address:	
Exemption Ref No:	NRW-WQE073840
Address where the operation can be carried out:	Glebe Cottage Llantillio Pertholey Nr Abergavenny Abergavenny Monmouthshire NP7 6NU
NGR:	SO 31170 16255

### Activity Number & Description:

#### 2 Operations

##### 2.1 Permitted activities

2.1.1 004 - Discharge of sewage effluent in to ground of two cubic metres per day or less. First made before 6 April 2010.

##### 2.2 The site

2.2.1 The maximum daily volume of the discharge shall be 2 cubic metres or less per day, as calculated by the method specified in the septic tank and sewage treatment plant manufacturer's and installer industry Code of Practice 'Flows and Loads 4'.

2.2.2 The sewage shall be solely domestic in origin and contain no trade effluent.

2.2.3 Prior to the discharge, the sewage must have received adequate treatment from a septic tank or sewage treatment plant designed and constructed according to the relevant British Standard design requirements in force at the time of installation.

2.2.4 The infiltration system or drainage field must have been installed in accordance with the relevant siting, design and installation requirements in force at the time of installation, including British Standard, if applicable.

2.2.5 The Discharge can only be made to a self contained infiltration system or drainage field without any observable discharge into surface waters.

2.2.6 The sewage treatment system must be installed in accordance with the manufacturer's specification issued at the time of installation or to the guidance given in the appropriate septic tank and package sewage treatment plant industry operating Code of Practice.

Ffôn/Tel 0300 065 3000  
Ffacs/Fax 0844 892 0845  
Ebost/Email [ymholiadau@cyfoethnaturiolcymru.gov.uk](mailto:ymholiadau@cyfoethnaturiolcymru.gov.uk)  
[enquiries@naturalresourceswales.gov.uk](mailto:enquiries@naturalresourceswales.gov.uk)

Canolfan Gwasanaethau Cwsmeriaid, Cyfoeth Naturiol Cymru, Ty Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP  
Customer Contact Centre, Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website [www.cyfoethnaturiolcymru.gov.uk](http://www.cyfoethnaturiolcymru.gov.uk)  
[www.naturalresourceswales.gov.uk](http://www.naturalresourceswales.gov.uk)

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg  
Correspondence welcomed in Welsh and English

2.2.7 The location of the discharge must be outside a Source Protection Zone 1 and be further than 50 metres from a permitted water supply or other source of private water supply.

2.2.8 The sewage treatment system shall be operated and maintained in accordance with a maintenance plan as specified within the manufacturer's maintenance instructions or other maintenance schedule adopted by the occupier, or manufacturing industry Code of Practice guides.

2.2.9 Maintenance should be undertaken by those who are competent in respect of the responsibilities to maintain and service the sewage treatment system.

2.2.10 Waste sludge removed from the sewage treatment system must be safely disposed of in an appropriate or controlled manner, using competent disposal contractors.

2.2.11 Records demonstrating compliance with the maintenance and desludging requirements shall be in a legible format and retained for at least 5 years from the date when the records were made.

2.2.12 The discharge must not cause pollution of surface or groundwater.

2.2.13 Details of this registration and associated conditions should be stored in a safe place, and provided to next occupier on change of ownership.

**Date of issue:** 10/05/2022

Ffôn/Tel 0300 065 3000  
Ffacs/Fax 0844 892 0845  
Ebost/Email [ymholiadau@cyfoethnaturiolcymru.gov.uk](mailto:ymholiadau@cyfoethnaturiolcymru.gov.uk)  
[enquiries@naturalresourceswales.gov.uk](mailto:enquiries@naturalresourceswales.gov.uk)

Canolfan Gwasanaethau Cwsmeriaid, Cyfoeth Naturiol Cymru, Ty Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP  
Customer Contact Centre, Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website [www.cyfoethnaturiolcymru.gov.uk](http://www.cyfoethnaturiolcymru.gov.uk)  
[www.naturalresourceswales.gov.uk](http://www.naturalresourceswales.gov.uk)

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg  
Correspondence welcomed in Welsh and English