
From: Wayne Lewis
Sent: 20 June 2023 12:57
To: Holly Nash
Subject: Fwd: 2 Market Place & 1 High Street, Woodstock

Sent from my iPhone

Begin forwarded message:

[REDACTED]
Date: 8 June 2023 at 12:41:13 BST

[REDACTED]
Subject: Fwd: 2 Market Place & 1 High Street, Woodstock

Sent from my iPhone

Begin forwarded message:

From: Jeremy Collins - Ironwood Structural Design
<jeremy@ironwood-design.co.uk>
Date: 8 June 2023 at 10:12:11 BST
To: Wayne Lewis <wayne@lewisproperty.co.uk>
Subject: 2 Market Place & 1 High Street, Woodstock

Dear Wayne

Further to our meeting at Brothertons Brasserie yesterday afternoon I write to confirm my observations:

1. There does indeed appear to be an infilled door opening between the 2 units, approx. 250mm / 1 brick thick, within a much thicker original wall.
2. The internal face to 1 High Street appears to have a cement render on it, indicating that it is relatively modern.
3. The timber lintel over, where exposed, appears to be in reasonable condition.

In summary, I cannot see a reason why the opening is not reintroduced. The works should proceed with care.

I trust that this is suitable for your needs but do let me know if you have any further questions relating to this.

Kind regards,

Jeremy

Jeremy Collins
Structural Engineer



[REDACTED]

[REDACTED]

From: Wayne Lewis <[REDACTED]>

Sent: Wednesday, June 7, 2023 2:36 PM

To: Jeremy Collins - Ironwood Structural Design [REDACTED]

Subject: Fwd:

Sent from my iPhone

Begin forwarded message:

From: Mevlan Karaj

Date: 2 June 2023 at 09:40:15 BST

To: Wayne Lewis [REDACTED]

Sent from my iPhone