



	Indoor Ref	Manufacturer	Model	Power Supply Required	Outdoor Ref	Manufacturer	Model	Power Supply Required
Restaurant	AC01	Daikin	FCAG50B		CU01	Daikin	RXM50R	1x 16A 1ph
Kitchen	AC02	Daikin	FBA71A		CU02	Daikin	ARXM71R	1x 16A 1ph
Chiller	EV01	Searle	TEC3.5-7	1x 16A 3ph to the controller	CU03	Danfoss	MSYM012MPW05G	1x 16A 1ph
Freezer	EV02	Searle	KEC25-6L	1x 16A 3ph to the controller	CU04	Danfoss	LSQM048NTW05G	1x 32A 1ph
WCs	EF01	Systemair	150dia Inline Fan	on light supply for toilet				
BACK OF HOUSE	KEF01	Systemair	MUBT450	1x 20A 3ph				
BACK OF HOUSE	KSF01	Systemair	AR400	1x 10A 1ph				

GENERAL NOTES:



SITE: BURGER KING- HEMSWORTH
 CLIENT: ADIL GROUP DRAWING BY: AC CHECKED BY: TS
 TITLE: PROPOSED AIR CONDITIONING & VENTILATION
 DATE: SCALE: PAPER SIZE: A1
 DRAWING NO. QI02099-AG-00-DR-01 REV 0