



Telephone 01202 744 966

REF: MC_2022_25639	DATE: 04/08/2023	TYPE: Building Control
--------------------	------------------	------------------------

ADDRESS: The Coal Yard Vicarage Lane, Hordle, Hampshire SO41 0HS
SURVEYOR: Jack French
WEATHER: Dry

**Report**

I attended the site as requested to carry out a commencement inspection to the foundations of plot 4. A section of 600mm wide strip foundation has been excavated for a length of approximately 3m to a depth of approximately 900mm into a firm natural clay strata. I have said they are okay to continue at this depth as long as the ground conditions remain the same due to the lack of trees in the vicinity of the footings to this plot. The next inspection will be for the remaining footings.

