



SPECIFIC EXTRACTION RATE 1.9 CUBIC/ MTRS / SEC

ANTICIPATED SYSTEM RESISTANCE – EXTRACTION , SAY 400 pa EXTRACTION FAN , PROPOSE WOODS EC TWIN BOX 560

ANTICIPATED SYSTEM RESISTANCE – SUPPLY AIR , SAY 300 pa SUPPLY AIR FAN , PROPOSE WOODS EC TWIN BOX 450

EXTRACTION SYSTEM

SUPPLY AIR SYSTEM

 THE STUDIO 30 COLTNESS ROAD PLYMOUTH TEL 01752 257070  181601		DESCRIPTION	
		6 DERRYS CROSS KITCHEN	
DRAWN BY MARTIN PANNELL		OPTION 4 AGREED VENTILATION BLOCK DIAGRAM	
DATE 24/08/2023		DWG NO	REV
SIZE A3	THIS DRAWING IS COPYRIGHT	11357 VENT	
SCALE	1:50	SHEET	1 OF 1